


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Reno</b>	Fraction <b>SW 1/4 NE 1/4 NE 1/4</b>	Section number <b>13</b>	Township number <b>T 23 S</b>	Range number <b>R 5 E</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:		<b>2 mi E of Hutchinson, KS</b>		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>10</b> in. Completion date <b>1-23-76</b> Well depth <b>38</b> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
<b>Sandy topsoil</b>		<b>0</b>	<b>2</b>	9. Casing: Material <b>PIST</b> Height: <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>1 1/4</b> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <b>195</b> lbs./ft. Dia. <b>6</b> in. to <b>38</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
<b>F Sand w layers of clay</b>		<b>2</b>	<b>16</b>	10. Screens: Manufacturer's name <b>Jess + Howell</b> Type <b>RMP</b> Dia. <b>6"</b> Slot gauze <b>3/32</b> Length <b>15'</b> Set between <b>21</b> ft. and <b>36</b> ft. Gravel pack? <b>yes</b> Size range of material <b>1/4 - 1/2</b>		
<b>Clay w F-sand - yellow</b>		<b>16</b>	<b>32</b>	11. Static water level: <input type="checkbox"/> ft. below land surface Date <b>1-23-76</b> <b>4</b> ft. below land surface		
<b>F - Sand - yellow</b>		<b>32</b>	<b>36</b>	12. Pumping level below land surfaces: <b>35</b> ft. after <b>42</b> hrs. pumping <b>10</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>10</b> g.p.m.		
<b>Clay - yellow</b>		<b>36</b>	<b>38</b>	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>14</b> inches above grade		
				15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>6</b> ft.		
				16. Nearest source of possible contamination: <b>Boysen</b> ft. <b>60</b> Direction <b>E</b> Type <b>Septic</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	<b>60ft from proposed Septic Tank site. Owner will place cement slab around well.</b> <b>Jessie Blake</b>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Miller Water Well 137</b> Business name <b>Hutchinson, KS</b> License No. <b>1-23</b> Address <b>Jess Miller</b> Date <b>1-23-76</b> Signed <b>Jess Miller</b> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5