

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction SW 1/4 SE 1/4 NW 1/4	Section number 14	Township number T 23 S	Range number R 5 E
2. Distance and direction from nearest town or city: Hutchinson on Obie Road 1/2 south of Street address of well location if in city:				3. Owner of well: Wilbur Redd R.R. or street: 5202 Frank Rd City, state, zip code: Hutchinson Kan. 67501		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date 7/8/79 Well depth 30 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input checked="" type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
top soil		0		4		9. Casing: Material pl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 2.17 lbs./ft. Dia. 6 in. to 30 ft. depth Wall Thickness: inches Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 25
medium coarse sand		4		14		10. Screen: Manufacturer's name slotted plastic Type pl Dia. 6 Slot/gauze .065 Length 18 ft Set between 20 ft. and 30 ft. ft. and ft. Gravel pack? no Size range of material
course sand		14		20		11. Static water level: 15 ft. below land surface Date 7/8/79 mo./day/yr.
course gravel		20		30		12. Pumping level below land surfaces: 15 ft. after 1 hrs. pumping 13 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 15 g.p.m.
						13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.
						16. Nearest source of possible contamination: septic tank ft. 100 Direction west Type septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydra Well Contractors 351 Business name Hutchinson Kan RR #5 License No. Address Hutchinson Kan RR #5 Signed Sandy Oplaga Date 7/13/79 Authorized representative
18. Elevation:		19. Remarks: Customer knows that installation of concrete slab is regulation				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5