

1 LOCATION OF WATER WELL: County: Reno		Fraction SE 1/4 SE 1/4 NE 1/4	Section Number 16	Township Number T 23 S	Range Number R 5 EW																																										
Distance and direction from nearest town or city street address of well if located within city? 3401 E. 4th Street																																															
2 WATER WELL OWNER: RR#, St. Address, Box # : City, State, ZIP Code		Eaton Corporation Eaton Center Cleveland, Ohio 44114																																													
Board of Agriculture, Division of Water Resources Application Number:																																															
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: 62.0 ft. ELEVATION: 130.0 ft.																																													
		Depth(s) Groundwater Encountered 1 ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL 130 ft. below land surface measured on 10/26/88 Pump test data: Well water was . ft. after . hours pumping . gpm Est. Yield . gpm: Well water was . ft. after . hours pumping . gpm Bore Hole Diameter. 10.0 in. to . ft. and . in. to . ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes. No. X ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes No X																																													
		TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued . Clamped . 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded . 2 PVC 4 ABS 7 Fiberglass Threaded. X Blank casing diameter 4.0 in. to . ft. Dia. . in. to . ft. Dia. . in. to . ft. Casing height above land surface. 12.0 in. weight . lbs./ft. Wall thickness or gauge No. .																																													
		TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) . 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) .																																													
		SCREEN-PERFORATED INTERVALS: From 52 ft. to 62 ft. From . ft. to . ft. From . ft. to . ft. From . ft. to . ft. GRAVEL PACK INTERVALS: From 12 ft. to 62 ft. From . ft. to . ft. From . ft. to . ft. From . ft. to . ft.																																													
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other .																																															
Grout Intervals: From 0 ft. to 12.0 ft. From . ft. to . ft. From . ft. to . ft.																																															
What is the nearest source of possible contamination:																																															
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) Solvent Storage Direction from well? Northwest How many feet? ~ 1000 ft.																																															
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>7</td> <td>Sandy Clay; Dark Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td>7</td> <td>10</td> <td>Silty Sand; Light Greyish Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td>10</td> <td>40</td> <td>Sand; Light Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td>40</td> <td>60</td> <td>as above but light yellowish Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td>60</td> <td>62</td> <td>Shale; Reddish Brown</td> <td></td> <td></td> <td></td> </tr> <tr> <td colspan="6" style="height: 100px; vertical-align: bottom;"> Grout and casing variance granted 11/22/88 by Darryl Plummer. </td> </tr> </tbody> </table>						FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	0	7	Sandy Clay; Dark Brown				7	10	Silty Sand; Light Greyish Brown				10	40	Sand; Light Brown				40	60	as above but light yellowish Brown				60	62	Shale; Reddish Brown				Grout and casing variance granted 11/22/88 by Darryl Plummer.					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																																										
0	7	Sandy Clay; Dark Brown																																													
7	10	Silty Sand; Light Greyish Brown																																													
10	40	Sand; Light Brown																																													
40	60	as above but light yellowish Brown																																													
60	62	Shale; Reddish Brown																																													
Grout and casing variance granted 11/22/88 by Darryl Plummer.																																															
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was 1 constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 10/18/88 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 496 This Water Well Record was completed on (mo/day/yr) 11-9-88 under the business name of David Danie's by (signature) <i>David Danie's</i>																																															