


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 18	Township number T 23 S R 5	Range number 5
2. Distance and direction from nearest town or city: Street address of well location if in city: 700 EF Hutchinson				3. Owner of well: Eddie Mann R.R. or street: 700 EF City, state, zip code: Hutchinson, Ks. 67501		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 6-3-77 Well depth 36 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Black soil				0	3	9. Casing: Material PST Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.51 lbs./ft. Dia. 6 in. to 36 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1280
Clay yellow				3	5	10. Screen: Manufacturer's name Pump Co. Type PVC Dia. 6" Slot gauze 1030 Length 10' Set between 26 ft. and 36 ft. Gravel pack? yes Size range of material F-4"
Sand + gravel coarse				5	43	11. Static water level: 20 ft. below land surface Date 6-3-77
						12. Pumping level below land surfaces: 20 ft. after 1 hrs. pumping 20 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50+ g.p.m.
						13. Water sample submitted: No Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.
						16. Nearest source of possible contamination: Tight Sewer ft. 15 Direction W Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well Serv. 137 Business name Hutchinson, Ks. License No. Address Joe Miller Date 6-3-77 Signed Joe Miller Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						