

1 LOCATION OF WATER WELL: County: <b>RENO</b>		Fraction <b>SW 1/4 SW 1/4 NE 1/4</b>	Section Number <b>30</b>	Township Number <b>T 23 S</b>	Range Number <b>R 5 EW</b>
Distance and direction from nearest town or city street address of well if located within city? <b>GRABER WEST STAR Truck Stop, 2212 U.S. Hwy 50, Hutchinson, KS (mw-2)</b>					
2 WATER WELL OWNER: RR#, St. Address, Box # : City, State, ZIP Code :		<b>JAYHAWK CORP.</b> <b>PO BOX 8216</b> <b>WACO, TX 767502</b>			
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		Board of Agriculture, Division of Water Resources Application Number:			
		4 DEPTH OF COMPLETED WELL: <b>13.5</b> ft. ELEVATION: <b>1519.26</b> Depth(s) Groundwater Encountered: <b>7.0</b> ft. 2. <b>-</b> ft. 3. <b>-</b> ft. WELL'S STATIC WATER LEVEL: <b>8.5</b> ft. below land surface measured on mo/day/yr <b>5-13-93</b> Pump test data: Well water was <b>-</b> ft. after <b>-</b> hours pumping <b>-</b> gpm Est. Yield <b>-</b> gpm: Well water was <b>-</b> ft. after <b>-</b> hours pumping <b>-</b> gpm Bore Hole Diameter: <b>8</b> in. to <b>15.5</b> ft., and <b>-</b> in. to <b>-</b> ft. WELL WATER TO BE USED AS: 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes <b>-</b> No <b>X</b> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes <b>-</b> No <b>X</b>			
5 TYPE OF BLANK CASING USED:		5 Wrought iron 8 Concrete tile CASING JOINTS: Glued <b>-</b> Clamped <b>-</b> 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded <b>-</b> 4 PVC 4 ABS 7 Fiberglass Threaded <b>X</b>			
Blank casing diameter <b>2</b> in. to <b>3.5</b> ft., Dia <b>-</b> in. to <b>-</b> ft., Dia <b>-</b> in. to <b>-</b> ft.		Casing height above land surface <b>24</b> in., weight <b>-</b> lbs./ft. Wall thickness or gauge No. <b>40</b>			
TYPE OF SCREEN OR PERFORATION MATERIAL:		1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify) 12 None used (open hole)			
SCREEN OR PERFORATION OPENINGS ARE:		1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 7 Torch cut 10 Other (specify)			
SCREEN-PERFORATED INTERVALS:		From <b>13.5</b> ft. to <b>3.5</b> ft., From <b>-</b> ft. to <b>-</b> ft. From <b>-</b> ft. to <b>-</b> ft., From <b>-</b> ft. to <b>-</b> ft.			
GRAVEL PACK INTERVALS:		From <b>15.5</b> ft. to <b>2.5</b> ft., From <b>-</b> ft. to <b>-</b> ft. From <b>-</b> ft. to <b>-</b> ft., From <b>-</b> ft. to <b>-</b> ft.			
6 GROUT MATERIAL:		1 Neat cement 2 Cement grout 3 Bentonite 4 Other			
Grout Intervals: From <b>2.5</b> ft. to <b>0</b> ft., From <b>-</b> ft. to <b>-</b> ft.		What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage Direction from well? <b>S</b> How many feet? <b>120</b>			
FROM TO LITHOLOGIC LOG		FROM TO PLUGGING INTERVALS			
0	1.0	Topsoil (Grass)			
1.0	3.0	Dark Grey Silty Clay			
3.0	5.0	Grey Lt. Brown Sandy Silty Clay			
5.0	12.0	Lt. Brown Fine-med Grain Sand			
12.0	15.5	Lt. Brown MED-Coarse Grain Sand			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <b>5/11/93</b> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <b>416</b> This Water Well Record was completed on (mo/day/yr) <b>6/24/93</b> under the business name of <b>Terracon</b> by (signature) <i>[Signature]</i>					