


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 34	Township number T 23 S R 5 E	Range number 5
2. Distance and direction from nearest town or city: Street address of well location if in city:		2 1/2 mi SE of Hutchinson, Ks.		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 10 1/2 in. Completion date 5-12-77 Well depth 25 ft.		
5. Type and color of material		From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material PIST Height: <u> </u> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.95 lbs./ft. Dia. 6 in. to 25 ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gage No. 1200
						10. Screen: Manufacturer's name <u> </u> Type RMP Dia. 6" Slot/gauze .030 Length 5' Set between 20 ft. and 25 ft. <u> </u> ft. and <u> </u> ft. Gravel pack? yes Size range of material F-1/2"
(Use a second sheet if needed)						11. Static water level: <u> </u> mo./day/yr. 6 ft. below land surface Date 5-12-77
						12. Pumping level below land surfaces: 22 ft. after 12 hrs. pumping 18 g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield 18 g.p.m.
						13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade
						15. Well grouted? yes With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 2 ft. to 12 ft.
						16. Nearest source of possible contamination: ft. 60 Direction W Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <u> </u> Not installed Manufacturer's name Valley Model number S1208 HP 1/2 Volts 230 Length of drop pipe 30 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well Serv. 137 Business name <u> </u> License No. <u> </u> Address Hutchinson, Ks. 67501 Signed Joe Miller Date 6-5-77 Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5