

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: <u>Reno</u>	<u>SW 1/4 NE 1/4 NE 1/4</u>	<u>4</u>	T <u>23</u> S	R <u>6</u> E <u>(W)</u>

Distance and direction from nearest town or city street address of well if located within city?

3404 Homestead Hutchinson

2 WATER WELL OWNER:	Board of Agriculture, Division of Water Resources
RR#, St. Address, Box # : <u>3404 Homestead</u>	Application Number:
City, State, ZIP Code : <u>Hutchinson Kan. 67502</u>	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: <u>25</u> ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. <u>8</u> ft. 2. <u>8</u> ft. 3. <u>8</u> ft. WELL'S STATIC WATER LEVEL <u>8</u> ft. below land surface measured on mo/day/yr <u>4-24-90</u> Pump test data: Well water was <u>9</u> ft. after <u>1</u> hours pumping <u>30</u> gpm Est. Yield <u>50</u> gpm: Well water was <u>9</u> ft. after <u>1</u> hours pumping <u>30</u> gpm Bore Hole Diameter <u>9</u> in. to <u>10</u> ft., and <u>6</u> in. to <u>25</u> ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial <u>(7) Lawn and garden only</u> 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes <u>X</u> No <u>X</u> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes <u>X</u> No <u>X</u>

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <u>X</u> Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
<u>(2) PVC</u>	4 ABS	7 Fiberglass	10 Asbestos-cement
Blank casing diameter <u>6</u> in. to <u>15</u> ft., Dia. <u>15</u> in. to <u>25</u> ft., Dia. <u>25</u> in. to <u>25</u> ft.			
Casing height above land surface <u>12</u> in., weight <u>1250</u> lbs./ft. Wall thickness or gauge No. <u>250</u>			
TYPE OF SCREEN OR PERFORATION MATERIAL:	<u>(7) PVC</u>	10 Asbestos-cement	11 Other (specify)
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot	<u>(3) Mill slot</u>	6 Wire wrapped	9 Drilled holes
2 Louvered shutter	4 Key punched	7 Torch cut	10 Other (specify)
SCREEN-PERFORATED INTERVALS: From <u>15</u> ft. to <u>25</u> ft., From <u>15</u> ft. to <u>25</u> ft., From <u>15</u> ft. to <u>25</u> ft.			
GRAVEL PACK INTERVALS: From <u>15</u> ft. to <u>25</u> ft., From <u>15</u> ft. to <u>25</u> ft., From <u>15</u> ft. to <u>25</u> ft.			

6 GROUT MATERIAL:	1 Neat cement	<u>(2) Cement grout</u>	3 Bentonite	4 Other
Grout Intervals: From <u>2</u> ft. to <u>10</u> ft., From <u>2</u> ft. to <u>10</u> ft., From <u>2</u> ft. to <u>10</u> ft.				
What is the nearest source of possible contamination:	10 Livestock pens	14 Abandoned water well		
<u>(1) Septic tank</u>	4 Lateral lines	7 Pit privy	11 Fuel storage	15 Oil well/Gas well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	12 Fertilizer storage	16 Other (specify below)
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	13 Insecticide storage	
Direction from well? <u>West</u>			How many feet? <u>80</u>	

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	Sandy soil			
2	6	Sandy clay			
6	9	fine sand			
9	13	fine gravel			
13	25	medium gravel			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, <u>(2)</u> reconstructed, or <u>(3)</u> plugged under my jurisdiction and was completed on (mo/day/year) <u>4-24-90</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>193</u> This Water Well Record was completed on (mo/day/yr) <u>6-25-90</u> under the business name of <u>Price Water Well Servi</u> by (signature) <u>John Davenport</u>
