

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 4	Township number T 23 S	Range number R 6 E
2. Distance and direction from nearest town or city: Street address of well location if in city:		3401 Homestead Hutchinson		3. Owner of well: Fairbanks Const. Co. R.R. or street: 815 W. 13th City, state, zip code: Hutchinson Kan 67501		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: SEPTIC well house		6. Bore hole dia. 9 in. Completion date 5-4-76 Well depth 40 ft.		
5. Type and color of material		From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input checked="" type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Sandy top soil		0		3		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
brown sandy clay		3		5		9. Casing: Material Plas Height: Above or below Threaded <input type="checkbox"/> Welded blue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 6 in. to 40 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 175
fine gravel		5		7		10. Screen: Manufacturer's name J&L Type RMP Dia. 6" Slot/gauze 1/8 hole Length 10' Set between 30 ft. and 40 ft. ft. and ft. Gravel pack? No Size range of material
medium gravel		7		40		11. Static water level: <input type="checkbox"/> mo./day/yr. 7 ft. below land surface Date 5-4-76
						12. Pumping level below land surfaces: 7 1/2 ft. after 1 hrs. pumping 25 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 75 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: Pitless adapter 12 Inches above grade
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 8 ft.
						16. Nearest source of possible contamination: ft. 55 Direction N Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Price Water Well 193 Business name RR3 Hutchinson License No. Address John Davenport Date 8-77 Signed John Davenport Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						