

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction E 1/4 NW 1/4 NE 1/4	Section number 4	Township number T 23 S	Range number R 6 E
2. Distance and direction from nearest town or city: 3210 Home stead			3. Owner of well: Elmer Smith Const.			
Street address of well location if in city: Hutchinson			R.R. or street: RR #1			
			City, state, zip code: Nickerson Kan. 67561			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 in. Completion date 5-5-76 Well depth 40 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Driven <input checked="" type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Plas Height: above or below Threaded <input type="checkbox"/> Welded blue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 6 in. to 40 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1175		
5. Type and color of material				From	To	10. Screen: Manufacturer's name J & L
Sandy top soil				0	2	Type RMP Dia. 6"
brown sandy clay				2	5	Slot/gauze 1/8 hole Length 10'
fine gravel				5	7	Set between 30 ft. and 40 ft.
medium gravel				7	40	Gravel pack? NO Size range of material
						11. Static water level: <input type="checkbox"/> mo./day/yr. 7 ft. below land surface Date 5-5-76
						12. Pumping level below land surfaces: 7 1/2 ft. after 1 hrs. pumping 25 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 75 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 8 ft.
						16. Nearest source of possible contamination: ft. 55 Direction SE Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						18. Elevation:
						19. Remarks: well in garage
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Price Water Well 193 Business name RR3 Hutchinson License No. 8-1-77 Address John Davenport Date 8-1-77 Signed John Davenport Authorized representative