

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Reno</u>	Fraction <u>SE 1/4 NE 1/4 SW 1/4</u>	Section number <u>9</u>	Township number <u>T 23 S R 6</u>	Range number <u>6</u>
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>902 West Villa Dr. Hutchinson, Ks.</u>			3. Owner of well: <u>North American Investment Co</u> R.R. or street: <u>201 N Whiteside</u> City, state, zip code: <u>Hutchinson, Ks. 67501</u>			
4. Locate with "X" in section below: Sketch map: <div style="text-align: center;"> </div>			6. Bore hole dia. <u>8</u> in. Completion date <u>12-16-75</u> Well depth <u>30</u> ft.			
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <u>Plst</u> Height <u>above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>195</u> lbs./ft. Dia. <u>3</u> in. to <u>30</u> ft. depth Wall Thickness: inches or Dia. <u>in.</u> to <u>ft.</u> depth gauge No. <u>200</u>			
			10. Screen: Manufacturer's name <u>J&L</u> Type <u>RMP</u> Dia. <u>5</u> Slot/gauze <u>3/32"</u> Length <u>10'</u> Set between <u>20</u> ft. and <u>30</u> ft. <u>ft.</u> and <u>ft.</u> Gravel pack? <u>yes</u> size range of material <u>F-1/2"</u>			
			11. Static water level: <u>12</u> ft. below land surface Date <u>12-16-75</u> mo./day/yr.			
			12. Pumping level below land surfaces: <u>135</u> ft. after <u>12</u> hrs. pumping <u>22</u> g.p.m. <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>45</u> g.p.m.			
			13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>mo./day/yr.</u>			
			14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter			
			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat Cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>13</u> ft.			
			16. Nearest source of possible contamination: ft. <u>60</u> Direction <u>NE</u> Type <u>septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: <u>Not installed</u> Manufacturer's name <u>Valley</u> Model number <u>51206</u> HP <u>1/3</u> Volts <u>230</u> Length of drop pipe <u>20</u> ft. capacity <u>12</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Miller Water Well Serv. 137</u> Business name <u>Hutchinson, Ks.</u> License No. <u>1/4 1/4</u> Address <u>Free Milk</u> Date <u>12-16-75</u> Signed <u>Authorized representative</u>			
18. Elevation:		19. Remarks: <div style="text-align: center;">(Use a second sheet if needed)</div>				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						