

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Reno		Fraction NW 1/4 NE 1/4 SW 1/4		Section number 9		Township number 23		Range number 6	
1. Location of well:				3. Owner of well: Mrs Harms		Completion date 5-10-78			
2. Distance and direction from nearest town or city: 3707 W 9th Hutchinson				R.R. or street: Hutchinson, Ks. 67501		City, state, zip code:			
4. Locate with "X" in section below: 1 Mile				6. Bore hole dia. 10 in. Well depth 32 ft.		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material				From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sandy soil				0		6		9. Casing: Material PVC Height: 12 in. Threading: Welded Surface: 1.95 lbs./ft. RMP: 1.95 PVC: 1.95 Weight: 1.95 lbs./ft. Dia. 6 in. to 32 ft. depth: 200 gage No. 200	
gray clay				6		12		10. Screen: Manufacturer's name Sunflower Type RMP Dia. 6 in. Slot gauge .060 Length 10 ft. Set between 22 ft. and 32 ft. Gravel pack? yes Size range of material F-1/2	
sand + gravel				12		35		11. Static water level: 9 ft. below land surface Date 5-10-78	
								12. Pumping level below land surfaces: 10 ft. after 1 hrs. pumping 20 g.p.m. 0 ft. after 0 hrs. pumping 0 g.p.m. Estimated maximum yield 50+ g.p.m.	
								13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 5-10-78	
								14. Well head completion: 12 Pitless adapter 12 inches above grade	
								15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
								16. Nearest source of possible contamination: 50 ft. E Direction E Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Miller Water Well Model number 137 HP 137 Volts 137 Length of drop pipe 137 ft. capacity 137 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:				19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well 137 Business name Hutchinson, Ks. License No. 6-7-78 Address Joe Miller Date 5-10-78 Signed Joe Miller Authorized representative			