


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction NE 1/4 SE 1/4 SW 1/4	Section number 9	Township number T 23	Range number S R 6 E (W)
2. Distance and direction from nearest town or city:		3. Owner of well:		Street address of well location if in city:		
703 West 11th Dr.		North America Investment Co.		201 N. White St.		
Hutchinson, Ks.		City, state, zip code:		Hutchinson, Ks. 67501		
4. Locate with "X" in section below:				Sketch map:		
				6. Bore hole dia. 8 in. Completion date 12-16-75 Well depth 35 ft.		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Sandy Topsail				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
Clay dk gray				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
Sand & Gravel light gray				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PLST Height 5 or below		
				Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 13 in.		
				RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.5 lbs./ft.		
				Dia. 5 in. to 35 ft. depth Wall Thickness: inches or		
				Dia. 5 in. to 35 ft. depth gage No. 200		
				10. Screen: Manufacturer's name IT&L		
				Type RMP Dia. 5"		
				60/ gauge 3/32" Length 10'		
				Set between 25 ft. and 35 ft.		
				Gravel pack? yes Size range of material F-5"		
				11. Static water level: 10 ft. below land surface Date 12-16-75		
				12. Pumping level below land surfaces:		
				12 ft. after 7 hrs. pumping 20 g.p.m.		
				ft. after 50 hrs. pumping 50 g.p.m.		
				Estimated maximum yield 50 g.p.m.		
				13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 12-16-75		
				14. Well head completion:		
				<input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? yes		
				With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete		
				Depth: From 7 ft. to 12 ft.		
				16. Nearest source of possible contamination:		
				ft. 35 Direction W Type Septic		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump:		
				Manufacturer's name Valley Not installed		
				Model number S1206 HP 1/3 Volts 230		
				Length of drop pipe 20 ft. capacity 12 g.p.m.		
				Type:		
				<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:				This well was drilled under my jurisdiction and this report		
<input type="checkbox"/> Hill				is true to the best of my knowledge and belief.		
<input type="checkbox"/> Slope				Miller Water Well 137		
<input checked="" type="checkbox"/> Upland				Business name Hutchinson, Ks.		
<input checked="" type="checkbox"/> Valley				Address Hutchinson, Ks.		
				Signed Joe Miller Date 4-16-76		
				Authorized representative		

23 - 6E - 9 NE SE SW
T R Sec 1/4 1/4 1/4