


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>RENO</b>	Township name <b>RENO</b>	Fraction <b>NE NE NE</b>	Section number <b>27</b>	Town number <b>T-23 S</b>	Range number <b>R 6 W</b>
Distance and direction from nearest town or city:			3 Owner of well: <b>Leroy Stuckey</b>			
Street address of well location if in city: <b>1507 W Blanchard</b>			Address: <b>RT 2 Pretty Prairie, KS</b>			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map: <b>S. Hutchinson, KS</b>			
2 Type and color of material			From	To	4 Well depth: <b>52</b> ft. Date of completion <b>7-31-75</b> Well diameter <b>10</b> in.	
<b>Sandy Top soil</b>			<b>0</b>	<b>5</b>	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<b>Brown dirt</b>			<b>5</b>	<b>14</b>	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
<b>Brown clay</b>			<b>14</b>	<b>21</b>	7 Casing: Material <b>RMP</b> Height: <b>above</b> below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>14</b> in. Dia. <b>6</b> in. to <b>52</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<b>Sand</b>			<b>21</b>	<b>40</b>	8 Screen: Manufacturer <b>Sunflower</b> Type <b>RMP</b> Dia. <b>6"</b> Star gauge <b>3/16"</b> Length <b>20'</b> Set between <b>32</b> ft. and <b>52</b> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>rd gravel</b>	
<b>Coarse sand</b>			<b>40</b>	<b>52</b>	9 Static water level: <b>25</b> ft. below land surface Date <b>7-31-75</b>	
					10 Pumping level below land surfaces: <b>29</b> ft. after <b>1</b> hrs. pumping <b>30</b> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <b>85</b> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
					12 Well head completion: <b>14"</b> <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ____ Depth: From <b>0</b> ft. to <b>10</b> ft.	
					14 Nearest source of possible contamination: ft. <b>60</b> Direction <b>South</b> Type <b>Septic</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Jacobs</b> Model number <b>SARP</b> HP <b>1/2</b> Volts <b>115</b> Length of drop pipe <b>35</b> ft. capacity <b>6</b> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Miller Water Well 137</b> Business name <b>Hutchinson, KS</b> License No. ____ Address <b>Joe Miller</b> Date <b>8-4-75</b> Signed <b>Joe Miller</b> Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5