


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Harvey	Township name	Fraction NW¹/₄ of NW¹/₄ of SW¹/₄	Section number 6	Town number T24S	Range number R1W		
Distance and direction from nearest town or city: 1 Mi. E. & 1/2 Mi. S. of Halstead			3 Owner of well: City of Halstead Address: Halstead, Kansas					
Locate with "X" in section below: 			Sketch map:			4 Well depth: 150 ft. Date of completion 11/74 Well diameter 32 in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			Top soil		0	1	6 Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			Sandy clay		1	11	7 Casing: Material stl Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30 in. Diam. 16 in. to 123 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth	
			Med. to coarse sand & gravel		11	15	8 Screen: Manufacturer Layne Type 304 SS Dia. 16" Slot/gauze 6 Length 25' Set between 123 ft. and 148 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8 - 3/8	
			Tan clay		15	35	9 Static water level: 23.20 ft. below land surface Date 11/74	
			Fine to coarse sand & fine gravel w/clay		35	65	10 Pumping level below land surfaces: 96.6 ft. after 4 hrs. pumping 590 g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 600 g.p.m.	
			Green clay		65	69	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —	
			Fine to coarse sand & gravel		69	113	12 Well head completion: <input type="checkbox"/> Pitless adapter 30 inches above grade	
			Clay		113	117	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 20 ft. to 1 ft.	
			Fine to coarse sand & clay		117	125	14 Nearest source of possible contamination: NONE ft. 12 miles E City Sanitary Sewage Plant Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Fine to coarse sand & fine - med. gravel		125	148	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 76661 HP 75 Volts 440 Length of drop pipe 100 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
Blue shale		148	151	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address 1011 W. Harry St., Wichita Signed [Signature] Date 12/2/74				
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley								

