


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Harvey	Fraction Center of 1/4 1/4 NE 1/4	Section number 7	Township number T 24 S	Range number R 1 E W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 S 1 3/4 E of Halstead			3. Owner of well: Alfred Boehs R.R. or street: Isbella, OKla 73747 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 5/1/80 Well depth 145 ft.		
		open field		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Topsoil				0	1	9. Casing: Material C-Asb Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.
Clay				0	50	Dia. 16 in. to 145 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 314
Sand - Fine				50	70	10. Screen: Manufacturer's name Johnson Type Cem- Asbestos Dia. 16" Slot/gauze 1/4 Length 52' Set between 67 ft. and 93 ft.
Clay				70	90	Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8
Sand & Clay				90	95	11. Static water level: 35 ft. below land surface Date 5/1/80
Sand - Med				95	110	12. Pumping level below land surfaces: 44 ft. after 2 hrs. pumping 900 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1000 g.p.m.
Clay				110	117	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
Gravel				117	138	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
Clay				138	140	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Gravel				140	145	16. Nearest source of possible contamination: none ft. Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
(Use a second sheet if needed)						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless Model number 9206 HP 80 Volts <input type="checkbox"/> Length of drop pipe 70 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weninger Irrigation 238 Business name Maize License No. <input type="checkbox"/> Address <input type="checkbox"/> Signed K. Weninger Date 6/20/80 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						