


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County HARVEY	Township name SEdgwick	Fraction NE 1/4 - SE 1/4	Section number 33	Town number T-24-S	Range number R-1W		
Distance and direction from nearest town or city: 1 N TOWN			3 Owner of well: E.A. VASBURG					
Street address of well location if in city: 3 1/2 W 8th, Sedgwick			Address: 3 1/2 W 8th, Sedgwick, KNS					
Locate with "X" in section below: N  W S 1 Mile			Sketch map:			4 Well depth: 53 ft. Date of completion 4/21/75 Well diameter 10 in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Leam		0	5	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry yd. <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			" to Light brown clay		5	10	7 Casing: Material PVC Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. Diam. 2 1/2 lbs./ft. 24 in. to 30 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
			brown clay		10	15	8 Screen: Pipe Mon. Manufacturer OWN Cert. Test Type PVC Dia. 5" Slot/gauze .0468 Length 20' Set between 53 ft. and 33 ft. Fittings: 1/4 - 1/2" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material	
			dark brown clay		15	26	9 Static water level: 19 ft. below land surface Date 4/21/75	
			brown to grey clay		26	28	10 Pumping level below land surfaces: 21 ft. after 1 hrs. pumping 20 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 120 g.p.m.	
			Sandy grey clay		28	30	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
			Sand - med to coarse (clean)		30	51	12 Well head completion: 24" <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
			Grey clay		51	53	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 10 ft. to 0 ft.	
							14 Nearest source of possible contamination: ft. 200 ft Direction South Type City Sewer Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC 175 Business name License No. Address Box 26, Hesston Signed Paul Paul Date 4/21/75 Authorized representative					