

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County HARVEY	Township name SEdwick	Fraction NE 1/4 - SE 1/4	Section number 33	Town number T-24-S	Range number R-1-W
Distance and direction from nearest town or city: IN TOWN				3 Owner of well: Charles HARSIN		
Street address of well location if in city: 300 W 6th SEdwick				Address: Box 46-SEdwick - KANSAS		
Locate with "X" in section below: <div style="text-align: center;">N S 1 Mile</div>				Sketch map: <div style="text-align: center; font-size: 2em; opacity: 0.5;">DAP</div>		
2				4 Well depth: 60 ft. Date of completion 4/17/75 Well diameter 5" in. bore-10"		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry y6. <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material PVC Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 5" Weight 2.20 lbs./ft. 5 in. to 60' ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth		
				8 Screen: pipe manufacturer Manufacturer PVC Cent-test Type PVC Dia. 5" Slot/gauze .064 Length 20' Set between 40 ft. and 60 ft. Fittings: 1/8 to 1/2" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
				9 Static water level: 20 ft. below land surface Date 4/17/75		
				10 Pumping level below land surfaces: 21 ft. after 1 hrs. pumping 20 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 100 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 10 ft. to 0' ft.		
				14 Nearest source of possible contamination: ft. 40' Direction EAST Type Sewer Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)				16 Remarks: elevation		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC 175 Business name License No. Address Box 26 Hesston Signed Paul Paul Date 4/17/75 Authorized representative		

Topography:
☐ Hill
☐ Slope
☐ Upland
☒ Valley