


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Harvey	Fraction SW 1/4 SW 1/4 SW	Section number 33	Township number T 24	Range number S R 1W E
2. Distance and direction from nearest town or city: 803 Madison Street address of well location if in city: Sedgwick, Kansas			3. Owner of well: Orivelle Eshelman R.R. or street: 803 Madison City, state, zip code: Sedgwick, Kansas			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 11 in. Completion date 3-18-77 Well depth 86 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 86 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200			
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauge 06 Length 40" Set between 50 ft. and 90 ft. Gravel pack? yes Size range of material 1/4-1/8"			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 25 ft. below land surface Date 3-18-77			
(Use a second sheet if needed)			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____			
			14. Well head completion: capped ____ Pitless adapter 12 Inches above grade			
			15. Well grouted? yes With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 40 ft.			
			16. Nearest source of possible contamination: city ft. 100 Direction east Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No			
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 4-19-77 Authorized representative			
			19. Remarks:			
			19. Remarks:			
			19. Remarks:			