

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number					
County: Stafford		SW 1/4 NW 1/4 SW 1/4		4		T 24 S		R 12w E/W					
Distance and direction from nearest town or city? In 3w Stafford, Ks.					Street address of well if located within city?								
2 WATER WELL OWNER: H-30 Drlg Inc					Board of Agriculture, Division of Water Resources								
RR#, St. Address, Box #: 200 N Main					Application Number: unknown								
City, State, ZIP Code: Wichita, Ks. 67202													
3 DEPTH OF COMPLETED WELL: 100 ft. Bore Hole Diameter: 8 in. to 100 ft., and in. to ft.													
Well Water to be used as:					5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well								
Well's static water level: 25 ft. below land surface measured on 10 month 25 day 78 year													
Pump Test Data: Well water was ft. after hours pumping gpm													
Est. Yield 65 gpm: Well water was ft. after hours pumping gpm													
4 TYPE OF BLANK CASING USED:					Casing Joints: Glued Clamped								
1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded													
2 PVC 4 ABS 7 Fiberglass Threaded													
Blank casing dia 5 in. to 60 ft., Dia in. to ft., Dia in. to ft.													
Casing height above land surface 12 in., weight 2.8 lbs./ft. Wall thickness or gauge No sch 40													
TYPE OF SCREEN OR PERFORATION MATERIAL:					7 PVC 10 Asbestos-cement								
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)													
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)													
Screen or Perforation Openings Are:					5 Gauzed wrapped 8 Saw cut 11 None (open hole)								
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes													
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)													
Screen-Perforation Dia 5 in. to ft., Dia in. to ft., Dia in. to ft.													
Screen-Perforated Intervals: From 60 ft. to 100 ft., From ft. to ft., From ft. to ft.													
Gravel Pack Intervals: From 10 ft. to 100 ft., From ft. to ft., From ft. to ft.													
5 GROUT MATERIAL:					3 Bentonite 4 Other								
1 Neat cement 2 Cement grout 3 Bentonite 4 Other													
Grouted Intervals: From 0 ft. to 10 ft., From ft. to ft., From ft. to ft.													
What is the nearest source of possible contamination:					10 Fuel storage 14 Abandoned water well								
1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well													
2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)													
3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines													
Direction from well se How many feet 70 ? Water Well Disinfected? Yes No													
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample													
was submitted month day year Pump Installed? Yes No													
If Yes: Pump Manufacturer's name Model No. HP Volts													
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.													
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other													
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 10 month 26 day 78 year													
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 186													
This Water Well Record was completed on 2 month 13 day 80 year under the business name of Kellys Waterwell Serv. by (signature) <i>Kelly Price</i>													
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:													
		FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
		0		30		Top Soil-Clay							
		30		55		Sand-Clay							
		55		100		Sand-Gravel							
ELEVATION: unknown													
Depth(s) Groundwater Encountered 1. 30 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)													
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.													

OFFICE USE ONLY

T

24

R

12

EW

SEC

4

SW 1/4

NW 1/4

SW 1/4