


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Shawnee</u>	Fraction <u>Center 1/4 SW 1/4 SW 1/4</u>	Section number <u>5</u>	Township number <u>T 24 S</u>	Range number <u>R 13 E</u>
2. Distance and direction from nearest town or city: Street address of well location if in city:		<u>1.5 West St John</u>		3. Owner of well: <u>adurambo drilling co.</u> R.R. or street: City, state, zip code: <u>Great Bend Kansas</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>5</u> in. Completion date <u>9-29-76</u> Well depth <u>65</u> ft.		
				7. <u>Rotary</u> Cable tool <u>Rotary</u> Driven <u>Dug</u> <u>Hollow rod</u> Jetted <u>Bored</u> Reverse rotary		
5. Type and color of material		From		To		8. Use: <u>Oil field water</u> Domestic <u>Public supply</u> Industry <u>Irrigation</u> Air conditioning <u>Stock</u> <u>Lawn</u> <u>Other</u>
<u>Plast</u>						9. Casing: Material <u>Plastic</u> Height: Above or below Threaded <u>Weld</u> Surface <u>12</u> in. RMP <u>PVC</u> Weight <u>287.5</u> lbs./ft. Dia. <u>5</u> in. to <u>65</u> ft. depth Wall Thickness: inches or Dia. <u>in.</u> to <u>ft.</u> depth Gauge No. <u>200</u>
<u>Sand & clay</u>		<u>0</u>		<u>30</u>		10. Screen: Manufacturer's name <u>Shop Made</u> Type <u>Sand</u> Dia. <u>5</u> Slot <u>1/8</u> Length <u>30</u> Set between <u>0</u> ft. and <u>65</u> ft. Gravel pack? <u>X</u> Size range of material <u>1/4-1/2</u>
<u>Gravel</u>		<u>30</u>		<u>45</u>		11. Static water level: <u>16</u> ft. below land surface Date <u>9-29-76</u> <u>mo./day/yr.</u>
						12. Pumping level below land surfaces: <u>20</u> ft. after <u>30</u> hrs. pumping <u>80</u> g.p.m. <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>150</u> g.p.m.
						13. Water sample submitted: <u>mo./day/yr.</u> Yes <u>X</u> No Date
						14. Well head completion: <u>Pitless adapter</u> <u>12</u> inches above grade
						15. Well grouted? <u>X</u> With: <u>Neat cement</u> <u>Bentonite</u> <u>Concrete</u> Depth: From <u>0</u> ft. to <u>10</u> ft.
						16. Nearest source of possible contamination: ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <u>Yes</u> <u>No</u>
						17. Pump: <u>X</u> Not installed Manufacturer's name Model number <u>HP</u> <u>Volts</u> Length of drop pipe <u>ft.</u> capacity <u>g.p.m.</u> Type: <u>Submersible</u> <u>Turbine</u> <u>Jet</u> <u>Reciprocating</u> <u>Centrifugal</u> <u>Other</u>
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Meyer Water Well Service</u> Business name License No. <u>1430</u> Address <u>Great Bend Kansas</u> Signed <u>[Signature]</u> Date <u>10-7-76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5