


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County STAFFORD	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 7	Township number T 24 S	Range number R 13 W
2. Distance and direction from nearest town or city: ST. JOHN Street address of well location if in city: 14 SOUTH 2 WEST		3. Owner of well: L. D. DRIG. R.R. or street: 915 KENNEDY City, state, zip code: GREAT BEND KANSAS 67530				
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 9 in. Completion date 11-25-78 Well depth 60 ft.		
5. Type and color of material		From	To	7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
				8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☒ Oil field water ☐ Other		
				9. Casing: Material ☐ Height: Above or below Threaded ☐ Welded ☒ Surface 12 in. RMP ☐ PVC ☒ Weight 278-3 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inch # or Dia. ☐ in. to ☐ ft. depth gage No. 200, 265		
				10. Screen: Manufacturer's name Peerless Type Saw Dia. 5 Slot/gouze 1/4" Length 20 Set between 60 ft. and 40 ft. ☐ ft. and ☐ ft. Gravel pack? yes Size range of material 1/8-1/4		
				11. Static water level: ☐ mo./day/yr. 20 ft. below land surface Date 11-25-78		
				12. Pumping level below land surfaces: ☐ ft. after ☐ hrs. pumping ☐ g.p.m. ☐ ft. after ☐ hrs. pumping ☐ g.p.m. Estimated maximum yield ☐ g.p.m.		
				13. Water sample submitted: ☐ Yes ☒ No Date ☐ mo./day/yr.		
				14. Well head completion: ☐ Pitless adapter 12 inches above grade		
				15. Well grouted? yes With: ☐ Neat cement ☒ Bentonite ☐ Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: None ft. ☐ Direction ☐ Type ☐ Well disinfected upon completion? ☐ Yes ☒ No		
				17. Pump: ☐ Not installed Manufacturer's name ☐ Model number ☐ HP ☐ Volts ☐ Length of drop pipe ☐ ft. capacity ☐ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Myers Water Well 143 Business name Great Bend KS License No. ☐ Address Great Bend KS Signature Elroy Rosemond Date 11-25-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5