

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <i>Stafford</i>	Fraction <i>C 1/4 NW 1/4 SW 1/4</i>	Section number <i>22</i>	Township number <i>T 24 S R 14 E/W</i>	Range number <i>14</i>
2. Distance and direction from nearest town or city: <i>1 mi east 1 3/4 mi south of Dillon, KS.</i> Street address of well location if in city:				3. Owner of well: <i>B F N Drilling Co.</i> R.R. or street: <i>Box 846</i> City, state, zip code: <i>Independence, KS</i>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <i>4 1/8</i> in. Completion date <i>5-26-77</i> Well depth <i>60</i> ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <i>PVC</i> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <i>24</i> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <i>160</i> lbs./ft. Dia. <i>4</i> in. to <i>60</i> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <i>1277</i>		
<i>Top soil</i>		<i>0</i>	<i>2</i>	10. Screen: Manufacturer's name <i>Carhart</i> Type <i>rule</i> Dia. <i>4</i> Slot/gauze <i>1/16</i> Length <i>20</i> Set between <i>1/40</i> ft. and <i>60</i> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <i>3/4/3/8</i> - <i>1/2</i>		
<i>Clay</i>		<i>2</i>	<i>5</i>	11. Static water level: <i>6</i> ft. below land surface Date <i>5-27-77</i> mo./day/yr.		
<i>Sand + gravel</i>		<i>5</i>	<i>8</i>	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping <i>NA</i> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
<i>Clay</i>		<i>8</i>	<i>12</i>	13. Water sample submitted: <i>Yes</i> <input checked="" type="checkbox"/> <i>No</i> <input type="checkbox"/> Date ____		
<i>Sand + gravel</i>		<i>12</i>	<i>38</i>	14. Well head completion: <input type="checkbox"/> Pitless adapter ____ inches above grade		
<i>Sand + gravel, clay mixed</i>		<i>38</i>	<i>40</i>	15. Well grouted? <i>NO</i> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From ____ ft. to ____ ft.		
<i>Sand + gravel</i>		<i>40</i>	<i>58</i>	16. Nearest source of possible contamination: ft. <i>75</i> Direction <i>EAST</i> Type <i>oil well</i> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
<i>Clay</i>		<i>58</i>	<i>60</i>	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Resenerantz, Bonis 13</i> Business name License No. <i>1/4 1/4</i> Address <i>Great Bend, KS</i> Signed <i>Andy Kilgore</i> Date <i>6/6/77</i> Authorized representative		
18. Elevation:		19. Remarks: <i>well will be pulled and plugged by customer</i>		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

T 24 S R 14 E  
 Sec 22  
 C NW SW  
 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5