

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Stafford	Fraction 1/4 1/4 CSW 1/4	Section number 25	Township number T 24 S	Range number R 14 E W
2. Distance and direction from nearest town or city: 7 1/2 miles Southwest of St. John, KS Street address of well location if in city:			3. Owner of well: Bill E. Koelsch R.R. or street: Route 1 City, state, zip code: St. John, KS 67576		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 24 in. Completion date 7-28- 76 Well depth 130 ft.
Top soil & brown clay			0	6	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Sand & gravel & clay streak at 13-35-44			6	51	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown clay			51	54	9. Casing: Material steel Height: above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.3 lbs./ft. Dia. 16 in. to 30 ft. depth Wall Thickness: 7 inches or Dia. 16 in. to 110 ft. depth gage No. 7 ga.
Sand & gravel			54	67	10. Screen: Manufacturer's name Doerr Type Double-slot Dia. 16" <input checked="" type="checkbox"/> Slot gauze 1/8" Length 60' Set between 30 ft. and 70 ft. 110 ft. and 130 ft. Gravel pack? yes Size range of material 3/8-200
Brown & gray clay & limestone			67	120	11. Static water level: 15' ft. below land surface Date 7-16-76 mo./day/yr.
Sand & gravel & lots of clay streaks			120	126	12. Pumping level below land surfaces: N/C ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
Dakota clay			126	130	13. Water sample submitted: ____ mo./day/yr. ____ Yes <input checked="" type="checkbox"/> No Date ____
					14. Well head completion: ____ Pitless adapter 12 inches above grade
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No
					17. Pump: Not installed Manufacturer's name PMC Corp./Peerless Model number 12LB-3 HP 80 Volts --- Length of drop pipe 70 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: ____ Hill ____ Slope ____ Upland ____ Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & eq. inc. 185 Business name License No. ____ Address Great Bend, KS 67530 Signed O.W. Clarke Date 7-30- 76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5