

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number					
County: Stafford		SE 1/4 SE 1/4 NE 1/4		24		T 24 S		R 15W E/W					
Distance and direction from nearest town or city? 2 1/2 mi. E, 1/2 S of Macksville, Kansas					Street address of well if located within city?								
2 WATER WELL OWNER:					Board of Agriculture, Division of Water Resources								
RR#, St. Address, Box # : Route 1					Application Number: None								
City, State, ZIP Code : Macksville, Kansas 67557													
3 DEPTH OF COMPLETED WELL: 80 ft. Bore Hole Diameter: 8 in. to 80 ft., and 80 in. to 80 ft.													
Well Water to be used as:													
1 Domestic		3 Feedlot		5 Public water supply		8 Air conditioning		11 Injection well					
2 Irrigation		4 Industrial		6 Oil field water supply		9 Dewatering		12 Other (Specify below)					
				7 Lawn and garden only		10 Observation well							
Well's static water level: 32 ft. below land surface measured on 1 month 24 day 1981 year													
Pump Test Data													
Est. Yield		60 gpm:		Well water was		ft. after		hours pumping					
				Well water was		ft. after		hours pumping					
4 TYPE OF BLANK CASING USED:													
1 Steel		3 RMP (SR)		5 Wrought iron		8 Concrete tile		Casing Joints: <u>Glued</u> Clamped					
2 PVC		4 ABS		6 Asbestos-Cement		9 Other (specify below)		Welded					
				7 Fiberglass				Threaded					
Blank casing dia: 5 in. to 60 ft., Dia: 60 in. to 60 ft., Dia: 60 in. to 60 ft.													
Casing height above land surface: 12 in., weight: 2.8 lbs./ft. Wall thickness or gauge No: Sch. 40													
TYPE OF SCREEN OR PERFORATION MATERIAL:													
1 Steel		3 Stainless steel		5 Fiberglass		7 PVC		10 Asbestos-cement					
2 Brass		4 Galvanized steel		6 Concrete tile		8 RMP (SR)		11 Other (specify)					
						9 ABS		12 None used (open hole)					
Screen or Perforation Openings Are:													
1 Continuous slot		3 Mill slot		5 Gauzed wrapped		8 Saw cut		11 None (open hole)					
2 Louvered shutter		4 Key punched		6 Wire wrapped		9 Drilled holes							
				7 Torch cut		10 Other (specify)							
Screen-Perforation Dia: 5 in. to 5 ft., Dia: 5 in. to 5 ft., Dia: 5 in. to 5 ft.													
Screen-Perforated Intervals: From 60 ft. to 80 ft., From 80 ft. to 80 ft., From 80 ft. to 80 ft.													
Gravel Pack Intervals: From 10 ft. to 80 ft., From 80 ft. to 80 ft., From 80 ft. to 80 ft.													
5 GROUT MATERIAL:													
1 Neat cement		2 Cement grout		3 Bentonite		4 Other							
Grouted Intervals: From 0 ft. to 10 ft., From 10 ft. to 10 ft., From 10 ft. to 10 ft.													
What is the nearest source of possible contamination:													
1 Septic tank		4 Cess pool		7 Sewage lagoon		10 Fuel storage		14 Abandoned water well					
2 Sewer lines		5 Seepage pit		8 Feed yard		11 Fertilizer storage		15 Oil well/Gas well					
3 Lateral lines		6 Pit privy		9 Livestock pens		12 Insecticide storage		16 Other (specify below)					
Direction from well: East How many feet: 150 ? Water Well Disinfected? <u>Yes</u> No													
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample													
was submitted month day year: Pump Installed? Yes No													
If Yes: Pump Manufacturer's name Model No. HP Volts													
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.													
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other													
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was													
completed on 1 month 24 day 1981 year													
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 186													
This Water Well Record was completed on 2 month 9 day 1981 year under the business													
name of Kellys Water Well Service by (signature) Kelly Price													
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:													
		FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
		0		58		Clay							
		58		80		Sand and Gravel							
ELEVATION: Unknown													
Depth(s) Groundwater Encountered 1... 32 ft. 2... ft. 3... ft. 4... ft. (Use a second sheet if needed)													

OFFICE USE ONLY

T

24

R

15

END

SEC.

24

SE 1/4 SE 1/4 NE 1/4