USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Ed Wards	1/4 1/4 CNW 1/4	5	T 24 S	R 16 E/W

2. Distance and direction from nearest town or city: 2 1/2 N
Street address of well location if in city: Belpre, Ks

3. Owner of well: C.D. Mitchell
R.R. or street: 5327 Woodson RD.
City, state, zip code: Mission, KS 66202

4. Locate with "X" in section below: Sketch map:

N
NW X NE
W E
SW SE
S
1 Mile 1 Mile

5. Type and color of materiol

	From	To
Top Soil - Clay	0	30
Sand - Gravel	30	50
Clay	50	57
Sand - Gravel	57	86
Clay	86	88

(Use a second sheet if needed)

6. Bore hole dia. 30 in. Completion date
Well depth 86 ft. 11-16-76

7. __ Cable tool __ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored X Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Steel Height: Above or below
Threaded ___ Welded X Surface 12 in.
RMP ___ PVC ___ Weight ___ lbs./ft.
Dia. 16 in. to 56 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 3/16"

10. Screen: Manufacturer's name Dorr
Type Steel Dia. 16
Slot/gauze 1/8" Length 30
Set between 56 ft. and 86 ft.
___ ft. and ___ ft.
Gravel pack? X Size range of material 1/8 - 3/4"

11. Static water level: mo./day/yr.
18 ft. below land surface Date 11-16-76

12. Pumping level below land surfaces:
49 ft. after 4 hrs. pumping 1100 g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 1200 g.p.m.

13. Water sample submitted: mo./day/yr.
X Yes ___ No Date 8-30-76

14. Well head completion:
___ Pitless adapter 12 Inches above grade

15. Well grouted? ___
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: Gas
ft. 1400 Direction S Type Well
Well disinfected upon completion? ___ Yes X No

17. Pump: Not installed
Manufacturer's name Goulds
Model number 3125 HP 60 Volts ___
Length of drop pipe 80 ft. capacity 900 g.p.m.
Type:
___ Submersible X Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

18. Elevation:

Topography:
___ Hill
___ Slope
X Upland
___ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Kelly's Water Well Ser 186
Business name License No.
Address R2 Great Bend, KS
Signed Kelly Price Date 12-4-76
Authorized representative

T 24 R 16 E/W Sec 5 1/4 CNW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023