


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction c 1/4 SW 1/4 SW 1/4	Section number 5	Township number T 24 S	Range number R 17 20 EW
2. Distance and direction from nearest town or city: 3 1/4 miles from Lewis, Ks. 3-N Street address of well location if in city:			3. Owner of well: L. G. Eddy R.R. or street: none City, state, zip code: Garfield, Kansas 67529		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 29 in. Completion date _____ Well depth 68 ft. 10-24-78		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To			9. Casing: Material steel Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 68 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 7		
			10. Screen: Manufacturer's name _____ Doerrs & Johnson Type steel Dia. _____ Slot xxx 3/16 Length 8-Doerrs 20-John- Set between 40 ft. and 68 ft. son _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8		
top soil			11. Static water level: _____ mo./day/yr. 22 ft. below land surface Date 8-3-78		
clay			12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 600 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1100 g.p.m.		
sand & gravel			13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 8-3-78		
clay			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
sand & gravel			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
clay			16. Nearest source of possible contamination: ft. 1900 Direction se Type farmstead Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)			17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, KS. 67530 Signed Sandy Kilgore Date 12-21-78 Authorized representative		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Customer furnished his own pump.				

T 24 S
 R 17 E
 Sec 5
 1/4 C SW SW
 1/4 1/4 SW SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5