


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: <u>Edwards</u> County		Fraction: <u>Quarter 1/4 SE 1/4 SW 1/4</u>	Section number: <u>10</u>	Township number: <u>T 24 S</u>	Range number: <u>R 17 E/W</u>		
2. Distance and direction from nearest town or city: Street address of well location in City: <u>West 2nd Street</u>			3. Owner of well: <u>Stirling Shilling Co.</u> R.R. or street: City, state, zip code: <u>Stirling, Kansas</u>				
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date: <u>9-16-76</u> Well depth <u>60</u> ft.			
5. Type and color of material		From		To			
		<u>Clay</u>		<u>0</u>	<u>20</u>	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		<u>Clay &amp; sand</u>		<u>20</u>	<u>40</u>	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		<u>Gravel</u>		<u>40</u>	<u>60</u>	9. Casing: Material <u>PVC</u> Height: Above or below Threaded <input type="checkbox"/> Welded <u>Blue</u> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2023</u> lbs./ft. Dia. <u>5</u> in. to <u>60</u> ft. depth; Wall Thickness: inches <u>or</u> Dia. <u>   </u> in. to <u>   </u> ft. depth; gage No. <u>1265</u>	
						10. Screen: Manufacturer's name <u>Stephens</u> Type <u>Slot</u> Dia. <u>5</u> Slot/gauge <u>1/8</u> Length <u>30</u> Set between <u>40</u> ft. and <u>60</u> ft. <u>   </u> ft. and <u>   </u> ft.	
						Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>5-44</u>	
						11. Static water level: <u>19</u> ft. below land surface Date <u>9-16-76</u> mo./day/yr.	
						12. Pumping level below land surfaces: <u>21</u> ft. after <u>1</u> hrs. pumping <u>60</u> g.p.m. <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. Estimated maximum yield <u>100</u> g.p.m.	
						13. Water sample submitted: <u>   </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u>   </u>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade <input checked="" type="checkbox"/> Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>30</u> ft.			
				16. Nearest source of possible contamination: ft. <u>   </u> Direction <u>   </u> Type <u>   </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>   </u> Model number <u>   </u> HP <u>   </u> Volts <u>   </u> Length of drop pipe <u>   </u> ft. capacity <u>   </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Nepes Water Well Service</u> Business name: <u>   </u> License No. <u>   </u> Address: <u>   </u> Signed: <u>   </u> Date: <u>9-16-76</u> Authorized representative			
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

T 24 S  
 R 17 E/W  
 Sec 10  
 1/4  
 1/4  
 1/4  
 1/4  
 CS 820

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5