

1 LOCATION OF WATER WELL	Fraction	Section Number	Township Number	Range Number
County: <u>Edwards</u>	$\frac{1}{4}$ <u>C</u> $\frac{1}{4}$ NE $\frac{1}{4}$	15	T 24 S	R 17 EW

Distance and direction from nearest town or city? 3 3/4 West, 3/4 North of Belpre  
 Street address of well if located within city?

2 WATER WELL OWNER: Dave Britton  
 RR#, St. Address, Box # :  
 City, State, ZIP Code : Lewis, Ks. 67552  
 Board of Agriculture, Division of Water Resources  
 Application Number: 32-322

3 DEPTH OF COMPLETED WELL: 85 ft. Bore Hole Diameter: 29 in. to 85 ft., and        in. to        ft.  
 Well Water to be used as:  
 1 Domestic    3 Feedlot    5 Public water supply    8 Air conditioning    11 Injection well  
 2 Irrigation   4 Industrial   6 Oil field water supply   9 Dewatering    12 Other (Specify below)  
 7 Lawn and garden only    10 Observation well  
 Well's static water level: 20 ft. below land surface measured on 10 month 27 day 80 year  
 Pump Test Data: Well water was 59 ft. after 1 hours pumping. 1100 gpm  
 Est. Yield 1300 gpm: Well water was 64 ft. after 1 1/2 hours pumping 1300 gpm

4 TYPE OF BLANK CASING USED:  
 Steel    3 RMP (SR)    5 Wrought iron    8 Concrete tile    Casing Joints: Glued    Clamped  
 PVC    4 ABS    6 Asbestos-Cement    9 Other (specify below)    Welded   
 7 Fiberglass    Threaded  
 Blank casing dia 16 in. to 61 ft., Dia        in. to        ft., Dia        in. to        ft.  
 Casing height above land surface: 18 in., weight        lbs./ft. Wall thickness or gauge No. 7

TYPE OF SCREEN OR PERFORATION MATERIAL:  
 Steel    3 Stainless steel    5 Fiberglass    8 RMP (SR)    10 Asbestos-cement  
 Brass    4 Galvanized steel    6 Concrete tile    9 ABS    11 Other (specify)         
 12 None used (open hole)  
 Screen or Perforation Openings Are:  
 1 Continuous slot    3 Mill slot    5 Gauzed wrapped    8 Saw cut    11 None (open hole)  
 2 Louvered shutter    4 Key punched    6 Wire wrapped    9 Drilled holes  
 7 Torch cut    10 Other (specify)         
 Screen-Perforation Dia 16 in. to 85 ft., Dia        in. to        ft., Dia        in. to        ft.  
 Screen-Perforated Intervals: From 61 ft. to 85 ft., From        ft. to        ft., From        ft. to        ft.  
 Gravel Pack Intervals: From 10 ft. to 90 ft., From        ft. to        ft., From        ft. to        ft.

5 GROUT MATERIAL:  Neat cement    2 Cement grout    3 Bentonite    4 Other  
 Grouted Intervals: From 0 ft. to 10 ft., From        ft. to        ft., From        ft. to        ft.  
 What is the nearest source of possible contamination:  
 1 Septic tank    4 Cess pool    7 Sewage lagoon    10 Fuel storage    14 Abandoned water well  
 2 Sewer lines    5 Seepage pit    8 Feed yard    11 Fertilizer storage    15 Oil well/Gas well  
 3 Lateral lines    6 Pit privy    9 Livestock pens    12 Insecticide storage    16 Other (specify below)  
 13 Watertight sewer lines  
 Direction from well NW How many feet 1,700? Water Well Disinfected? Yes HTH No  
 Was a chemical/bacteriological sample submitted to Department? Yes  No  
 was submitted 10 month 27 day 80 year: Pump Installed? Yes  No   
 If Yes: Pump Manufacturer's name        Model No. HP Volts         
 Depth of Pump Intake        ft. Pumps Capacity rated at        gal./min.  
 Type of pump:  1 Submersible     2 Turbine     3 Jet     4 Centrifugal     5 Reciprocating     6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 11 month 10 day 80 year  
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 134  
 This Water Well Record was completed on 11 month 14 day 80 year under the business name of Rosencrantz-Bemis by (signature) Yara Dodson

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	2	Top soil		
	2	6	Brown clay			
	6	8	Gray clay			
	8	11	Brown and white clay			
	11	16	Yellow, brown and gray sandy clay			
	16	19	Yellow, brown and gray clay mixed w/sand and gravel			
	19	51	Sand and gravel			
	51	55	Yellow clay			
	55	86	Sand and gravel w/yellow clay			
	86	90	Brown and white clay			

ELEVATION:  
 Depth(s) Groundwater Encountered 1. 20 ft. 2.        ft. 3.        ft. 4.        ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY  
T  
24  
R  
17  
SEC  
15  
1/4  
C of ME 1/4