


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 22	Township number T 24 S R 17 E/W	Range number 17 E/W
2. Distance and direction from nearest town or city: 5W of Belpre North side of Rd. Street address of well location if in city:			3. Owner of well: David Cross R.R. or street: City, state, zip code: Lewis Ks.		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 9 7/8 in. Well depth 85 ft. Completion date 8-23-76
Sandy Top; Soil			0	2	7. <input checked="" type="checkbox"/> Cable tool Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Fine Sand & Brown Clay			2	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown Sandy Clay			4	11	9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 160 lbs./ft. Dia. 6 in. 85 ft. depth; Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth; gage No. 1/4
Fine Sand & Gravel			11	21	10. Screen: Manufacturer's name _____ Type PVC Dia. 6 Slot/gauge 1/16 Length 20 Set between 65 ft. and 85 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8
Sand & Gravel Med Med.			21	49	11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 8-23-76
Sand & Gravel Clay Mix			49	58	12. Pumping level below land surfaces: NA _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Clean Coarse Sand & Gravel			58	86	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 8-23-76
Sand & Clay Gravel Little Clay Mix			86	88	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
Gray, White & Lt. Blue Clay			88	106	15. Well grouted? _____ With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 100 Direction NE Type Correll Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, Ks. 67530 Signed Fredia Dodson Date 4/8/79 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 24 S R 17 E Sec 22 NW 1/4 1/4 1/4 NUSSER

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5