


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: A-1	County Edwards	Fraction 1/4 C 1/4 SE 1/4	Section number 8	Township number T 24 S R 18 E/W	Range number
2. Distance and direction from nearest town or city: 3w. 2n. 1/4w. 1/4n into field from Edwards, ks			3. Owner of well: O.B. Adams R.R. or street: West Highway 59 City, state, zip code: Marion, Mo 6467846		
4. Locate with "X" in section below: N W E S 1 Mile  A-1			6. Bore hole dia. 2 1/2 in. Completion date Well depth 67 ft. 5-24-77		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia 2 1/2 in. to 64 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____		
			10. Screen: Manufacturer's name _____ Type Steel Dia. _____ Slot/gauge 3/16 Length 20 Set between 44 ft. and 64 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 to 3/4		
Top soil			11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 11-22-76		
Clay			12. Pumping level below land surfaces: 41 ft. after 1 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 600 g.p.m.		
Sand & gravel			13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 11-22-76		
Brown clay			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Sand rock			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: _____ Not installed Manufacturer's name W.L.B. Model number 4-12CM HP 600 Volts _____ Length of drop pipe 50 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name: Burris 134 License No. Address: West Bend, ks. 67530 Signed: Sandall Gore 11-27 Date Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 24 S R 18 E/W Sec 8 1/4 C 1/4 SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5