

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County EDWARDS		Fraction C/NW 1/4 1/4 1/4			Section number 11	Township number T 24 S	Range number R 18 EW
2. Distance and direction from nearest town or city: 3 W 2 3/4 N of Lewis, Ks. Street address of well location if in city:					3. Owner of well: Dwight Slentz R.R. or street: City, state, zip code: Lewis, Ks.		
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 		6. Bore hole dia. 2 1/2 in. Completion date _____ Well depth 75 ft. 5-4-76	
5. Type and color of material				From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
STANDY Top Soil				0	5	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown Clay				5	13	9. Casing: Material steel Height: <input checked="" type="checkbox"/> Above or <input type="checkbox"/> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to 7 1/2 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7	
Fine Sand				13	25	10. Screen: Manufacturer's name Doerr's Type steel Dia. 1 1/2 Slot/gauze 3/16 Length 28 Set between 47 ft. and 75 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8	
Sand & Gravel clean Coarse loose				25	54	11. Static water level: _____ mo./day/yr. 20 ft. below land surface Date 2-3-76	
Brown Clay				54	100	12. Pumping level below land surfaces: 20 ft. after 1/2 hrs. pumping 1200 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1300 g.p.m.	
Sand & sand rock				100	105	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
Fire Clay				105		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade	
						15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
						16. Nearest source of possible contamination: ft. 400 Direction W Type SEPTIC Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: _____ Not installed Manufacturer's name WLR Model number 3-5M-12 HP 80 Volts _____ Length of drop pipe 60 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)							
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz Bemis 134 Business name _____ License No. _____ Address Great Bend, Ks. Signed India Radom Date 9/29/76 Authorized representative			

24 18 W
 Sec 11 C NW
 1/4 1/4 1/4