

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Edwards		Fraction CSE 1/4 1/4 1/4 1/4			Section number 13		Township number T 24 S R 18 E/W		Range number		
2. Distance and direction from nearest town or city: 1 N 1 E					3. Owner of well: Bob McKinney						
Street address of well location if in city: Lewis, KS					R.R. or street: City, state, zip code: Lewis, Kan.						
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia. 30 in. Completion date 3-20-76 Well depth 78 ft.						
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary						
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other						
5. Type and color of material					9. Casing: Material Iron Height: Above _____ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 48 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 346						
					10. Screen: Manufacturer's name Doerr Type IRON Dia. 16" Slot/gauze 1/8 Length 30' Set between 48 ft. and 78 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 40-3/4"						
					11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 3-20-76						
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. 51 ft. after 4 hrs. pumping 1150 g.p.m. Estimated maximum yield 1150 g.p.m.						
					13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____						
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade						
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 14 ft.						
					16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No						
					17. Pump: _____ Not installed Manufacturer's name Goulds Model number 412 J HP 60 Volts _____ Length of drop pipe 70 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kelly's Water Well Ser 126 Business name _____ License No. _____ Address R2 Great Bend, KS Signed Kelly Puer Date 3-26-76 Authorized representative						
18. Elevation:		19. Remarks:									
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley											

T 24 S R 18 E/W
 Sec 13 CSE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5