USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

## WATER WELL RECORD KSA 820-1201-1215

Kansas Department of Health and Environment-Division of Environment (Woter well Contractors) Topeka, Kansos 66620

	County	Fraction				Section	number	Township number Range number	7	
1. Location of well:	Edwards	1/4 C 1/4 SW 1/4		1/4	22		T 24 S R 18 E/W			
2. Distance and direction from nearest town or city:  2 mi West of Lewis, Ks. on North side of  R.R. of Street address of well location if in city:					3. Owr	wner of well: or street:		Dwight Slentz none		
4. Locate with "X" in section below:  N  Sketch map:					City, s	state, zip code:		1.ewis, Kansas 67552  6. Bore hole dio. 29 in. Completion dote		
W - NE - E								7 Cable tool X Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary  8. Use: Domestic Public supply Industry		
							x Irrigation Air conditioning Stock Lawn Oil field water Other			
, <u>, , , , , , , , , , , , , , , , , , </u>								9. Casing: Material steel Height: Above or <b>polyw</b> Threaded Welded Surface in RMP PVC Weight lbs./ft  Dia. 16 in. to 108 ft. depth Wall Thickness: inches or		
5. Type and color of material						From	То	Diain. to ft. depth gage No 7		
Top Soil						0	2	10. Screen: Manufacturer's name	-	
• _					2	18	Slot/36363X 3/16 Length 48	-		
Brown clay  Fine sand & gravel w/brown & gray clay						18	22	Set between 60 ft. and 108 ft ft. and ft ft. and ft Grovel pack? X Size range of material 3/4 3/4 3/4 3/4 3/4 3/4 3/4 3/4 3/4 3/4	/β	
Sand & gravel						22	44	11. Static water level: mo./day/yr 27 ft, below land surface Date 2-10-77	Ż	
Brown and white clay					44	47	12. Pumping level below land surfaces:  50 ft. after 1 hrs. pumping 600 g.p.m.			
Sand & gravel						47	48	ft. after hrs. pumping g.p.m.  Estimated maximum yield 900 g.p.m.		
Brown and white clay						48	52	13. Water sample submitted: mo./day/yr X Yes Na Date 2-10-77	$\cdot$	
Sand and gravel					<del></del>	52	67	X Yes Na Date	1	
Rrama Brown and white clay						67	96	15. Well grouted?x	1	
Sand and gravel						96	97	With: X Neat cement Bentonite Concrete Depth: From ft. to ft.	-	
Brown and white clay						97	99	16. Negrest source of possible contamination: ft. 500 Direction NE Type gaswell		
Sand and gravel						99	106	Well disinfected upon completion? HTH YesN	읙	
Fire clay				106	108	17. Pump: X Not installed  Manufacturer's name	- ~			
	;							Length of drop pipe ft. capacityg.p.m.		
	· · · · · · · · · · · · · · · · · · ·							Type: Submersible Turbine Jet Reciprocating		
	(Use a second s	neet if needed)	)					Centrifugal Other	_  %	
18. Elevation: , 19. Remarks:								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report		
Topography:	S 124 1							is true to the best of my knowledge and belief.  Rosencrantz-Bemis 134	7	
Hill								Business name  Address Great Bend, Kansas 6753	:I	
Slape _X Upland Valley							:	Signed Authorized representative Date	<b>*</b>	