


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Cartoon

1. Location of well: County Edwards Fraction NW 1/4 NE 1/4 NE 1/4 Section number 23 Township number 24 Range number 18 E/W	
2. Distance and direction from nearest town or city: 1 north of west Lewis side south side Street address of well location if in city:	
3. Owner of well: Steeling Delg R.R. or street: Box 129 City, state, zip code: Steeling, Ks 67579	
4. Locate with "X" in section below: Sketch map: 	
6. Bore hole dia. 9 in. Completion date 3-12-79 Well depth 60 ft.	
7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Dia. 5 in. to 60 ft. depth 12 Surface 12 in. Weight 278-3 lbs./ft. Wall Thickness: 2 1/2 inches or gage No. 2 1/2	
5. Type and color of material	
	From To
Fine Sand	0 10
Clay	10 25
Brandy Clay	25 30
Gravel	30 60
10. Screen: Manufacturer's name Peerless Type 20W Dia. 5 Slot/gauze 1/8 Length 20 Set between 60 ft. and 40 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/4	
11. Static water level: 20 ft. below land surface Date 3-12-79 mo./day/yr.	
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____	
14. Well head completion: _____ Pitless adapter 12 Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination _____ ft. Direction _____ Type None Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Myers Water Well 143 Business name License No. Great Bend Ks 67530 Address Sign: Byrd Rosendall Date 3-12-79 Authorized representative	

T 24
 R 18
 W 23
 Sec NW NE NE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5