USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: Ewdwards	Fraction: NW / S½ / SW (1/4 1/4 1/4)	Section number: 30	Township number: T 24 S	Range number: R 18 E/W

2. Distance and direction from nearest town or city: 4 3/4 W 1/2 S 1/4 E of Lewis
Street address of well location if in city:

3. Owner of well: Willis McClaren
R.R. or street:
City, state, zip code: Lewis, Ks.

4. Locate with "X" in section below: Sketch map:

N — NW | NE — W — E — SW | SE — S — 1 Mile

6. Bore hole dia. 29 in. Completion date 5-27-76
Well depth 134 ft.

7. __ Cable tool ✓ Rotary __ Driven __ Dug __ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry ✓ Irrigation __ Air conditioning __ Stock __ Lawn __ Oil field water __ Other

9. Casing: Material Steel Height: Above or (below) Surface 18 in.
Threaded ___ Welded ✓ Weight ___ lbs./ft.
RMP ___ PVC ___ Wall Thickness: inches or gage No. 7
Dia. 16 in. to 134 ft. depth
Dia. ___ in. to ___ ft. depth

10. Screen: Manufacturer's name Roeris
Type Steel Dia. 16
Slot/gauze 3/16 Length 72
Set between 62 ft. and 134 ft.
___ ft. and ___ ft.
Gravel pack? ✓ Size range of material 1/2 3/4 3/8

11. Static water level: 25 ft. below land surface Date 1-29-76 (mo./day/yr.)

12. Pumping level below land surfaces: 28 ft. after 1/2 hrs. pumping 1200 g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 1400 g.p.m.

13. Water sample submitted: ✓ Yes ___ No Date 2-14-76 (mo./day/yr.)

14. Well head completion: ___ Pitless adapter ___ Inches above grade

15. Well grouted? ✓
With: ___ Neat cement ___ Bentonite ✓ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: ft. 6 M Direction W Type Septic
Well disinfected upon completion? ___ Yes ___ No

17. Pump: Not installed
Manufacturer's name W L R
Model number 3-MS-12 HP 80 Volts ___
Length of drop pipe 70 ft. capacity ___ g.p.m.
Type: ___ Submersible ✓ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other

5. Type and color of material	From	To
Top Soil	0	2
Brown Sandy Clay	2	16
Gray & White Sandy Clay	16	21
Fine Sand & Sandy Gray & White Clay	21	27
Sand & Gravel clean Coarse loose	27	78
Brown Clay	78	80
Fine Blue Sandy Clay & Fine Sand	80	115
Brown Sandy Clay	115	122
Sand & Gravel loose Med. Clean	122	132
Blue Gray Clay & Sand Rock	132	140

(Use a second sheet if needed)

18. Elevation:
Topography: ___ Hill ___ Slope ✓ Upland ___ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Rosencrantz - Bemis License No. 134
Address Great Bend, Ks.
Signed Fredia Dodson Date 9/29/76
Authorized representative

T 24 R 18 E/W Sec 30 1/4 NW 1/4 SE 1/4 SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023