


V? OK

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Edwards</u>		Fraction <u>C/SW</u> 1/4 1/4 1/4			Section number <u>34</u>		Township number <u>T 24 S R 18 E/W</u>		Range number			
2. Distance and direction from nearest town or city: <u>1 South 1/2 W of Lewis n side</u> Street address of well location if in city:					3. Owner of well: <u>Dave McClaren</u> R.R. or street: City, state, zip code: <u>Lewis, Ks.</u>							
4. Locate with "X" in section below: N W E S 1 Mile					Sketch map: 			6. Bore hole dia. <u>2 1/2</u> in. Completion date <u>12-11-74</u> Well depth <u>154 1/2</u> ft.				
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary							
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other							
					9. Casing: Material <u>Steel</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>1 1/2</u> in. to <u>1 5/8</u> in. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <u>7</u>							
5. Type and color of material					From		To		10. Screen: Manufacturer's name <u>Doerrs</u>			
<u>Sandy Top Soil</u>					<u>0</u>		<u>2</u>		Type <u>steel</u> Dia. <u>1 1/2</u>			
<u>Brown Sandy Clay</u>					<u>2</u>		<u>7</u>		8 in. gauge <u>3/16</u> Length <u>100</u>			
<u>Gray Clay</u>					<u>7</u>		<u>9</u>		Set between <u>54 1/2</u> ft. and <u>154 1/2</u> ft.			
<u>Brown Clay</u>					<u>9</u>		<u>16</u>		ft. and <u>3/8</u> ft.			
<u>Fine Sand</u>					<u>16</u>		<u>21</u>		Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2 3/4 3/8</u>			
<u>Sand & Gravel clean loose med coarse</u>					<u>21</u>		<u>58</u>		11. Static water level: <u>22</u> ft. below land surface Date <u>11-26-74</u> mo./day/yr. <u>74</u>			
<u>Gray Clay</u>					<u>58</u>		<u>59 1/2</u>		12. Pumping level below land surfaces: <u>21</u> ft. after <u>1</u> hrs. pumping <u>900</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1000</u> g.p.m.			
<u>Sand & Gravel clean loose med.</u>					<u>59 1/2</u>		<u>69</u>		13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date <u>11-30-74</u>			
<u>Brown & Gray Clay</u>					<u>69</u>		<u>76</u>		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
<u>Sand & Gravel, Brown Clay, white Rock Tough</u>					<u>76</u>		<u>83</u>		15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
<u>Sand & Gravel loose w/ Rock & Clay</u>					<u>83</u>		<u>90</u>		16. Nearest source of possible contamination: ft. <u>74</u> Direction <u>NW</u> Type <u>Septic tank</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			
<u>Clay & Sand mixed</u>					<u>90</u>		<u>95</u>		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>WLR</u> Model number <u>SCM12</u> HP <u>80</u> Volts <u> </u> Length of drop pipe <u>85</u> ft. capacity <u>900</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
<u>Sand & Gravel clean loose med.</u>					<u>95</u>		<u>101</u>					
<u>Brown Clay & white Rock</u>					<u>101</u>		<u>110</u>					
<u>Sand Rock</u>					<u>110</u>		<u>155</u>					
<u>Light Gray Shale</u>					<u>155</u>		<u>160</u>					
(Use a second sheet if needed)												
18. Elevation: <u>2155</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: <u>6530</u> <u>24 18 34 CAD</u>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosenkrantz-Bemis 134</u> Business name License No. Address <u>Great Bend Ks.</u> Signed <u>Fredrick Dawson</u> Date <u>9/3/76</u> Authorized representative							

T 24 S R 18 E S 34 CSW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5