


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

#4

| | | | | | | |
|--|-----------------------|--------------------------------|------------------------|---|-----------------------|------------------------|
| 1 Location of well: | County Edwards | Township name Wayne, Ws | Fraction BE 1/4 | Section number 35 | Tawn number 24 | Range number 18 |
| Distance and direction from nearest town or city: Street address of well location if in city: 1 1/2 W 3/4 S 1/4 E. LEWIS | | | | 3 Owner of well: Don McAllister Address: Box 181 Lewis, Kansas 67552 | | |
| Locate with "X" in section below: N  W E S 1 Mile | | | | Sketch map: | | |
| 2 | | | | 4 Well depth: 82 ft. Date of completion 3/18/75 Well diameter 16 in. | | |
| Type and color of material | | | | 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | | |
| From To | | | | 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> | | |
| soil 0 2 | | | | 7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 8 in. Diam. 16 in. to 56 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 30 lbs./ft. | | |
| clay 2 13 | | | | 8 Screen: Manufacturer Johanson Type slotted Dia. 16 Slot/gauze 3/16 Length 26 Set between 56 ft. and 82 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 18-3/16 | | |
| fine sand 13 15 | | | | 9 Static water level: 20 ft. below land surface Date 12/20/1974 | | |
| fine sand and clay mixed 15 20 | | | | 10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 1200 g.p.m. | | |
| gravel(good) 20 85 | | | | 11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____ | | |
| Test pumping | | | | 12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade | | |
| 1400 GPM 50 ft. Lift | | | | 13 Well grouted? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite 10 Depth: From 2 ft. to 10 ft. | | |
| 1200 GPM 48 ft. Lift | | | | 14 Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 1000 GPM 44 ft. Lift | | | | 15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Roller Model number 3870 RB HP 64 Volts ____ Length of drop pipe 60 ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| (use a second sheet if needed) | | | | 16 Remarks: elevation | | |
| Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | | | | 17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Darling Drilling Co. 189 Business name License No. Address: 211 West 4th, Hutchinson, Ks. Signed: Donald J. Darling Date 3-29-75 Authorized representative | | |

24 18W 35 CSE 1