


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 6	Township number 24	Range number 19
2. Distance and direction from nearest town or city: from Kinsley, Ks. 2w - 4n - 1e Street address of well location if in city:		3. Owner of well: Jerome Herrmann R.R. or street: Rt. 2 City, state, zip code: Kinsley, Kansas 67547			
4. Locate with "X" in section below: 		6. Bore hole dia. 11 in. Completion date _____ Well depth 115 ft. 8-16-79			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
top soil		0	2	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
clay		2	80	9. Casing: Material PVC Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP 5 1/2 _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 1/2 in. to 11 1/2 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. .258	
sand and gravel with clay		80	89	10. Screen: Manufacturer's name _____ certain teed Type PVC Dia. 5 1/2 Slot/groove 1/16 Length 20' Set between 95 ft. and 115 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8-1/2	
gravel, clay and rock		89	97	11. Static water level: _____ mo./day/yr. 49 ft. below land surface Date 8-9-79	
clay		97	101	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping NA g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
gravel, clay, and rock		101	114	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 8-9-79	
fire clay		114	140	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 90 Direction south Type corrall Well disinfected upon completion? HTH Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name Red Jacket Model number 9BC HP 1/2 Volts 230 Length of drop pipe 84 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: 2213'		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name Box 713 Great Bend, Ks. License No. _____ Address _____ Signed India Rodan Date 8/30/79 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T
R
S
E
1/4
1/4
1/4
1/4