


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Edwards	Township name Kinsley	Fraction center SW$\frac{1}{4}$	Section number 20	Town number 24	Range number 19
Distance and direction from nearest town or city: 1 mile N. 1/3 west of Kinsley, Ka.				3 Owner of well: Don Hirsh Address: Kinsley, Kansas		
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: 30 ft. Date of completion 5-9-75 Well diameter 8 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material plastic above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 1.8 lbs./ft. 5 in. to 30 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No 5 in. to 30 ft. depth		
				8 Screen: 10' Manufacturer Superior Type 15% Dia. 5 Slot/gauze 1/16 Length 4" Set between 20 ft. and 30 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/4"		
				9 Static water level: 14 ft. below land surface Date 5-9-75		
				10 Pumping level below land surfaces: 20 ft. after 1 hrs. pumping 10 g.p.m. ft. after 1 hrs. pumping 10 g.p.m. Estimated maximum yield 10 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 5-9-75		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: ft. no Direction no Type no Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Reda Model number 949p051 HP 1 Volts 220 Length of drop pipe 21 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Land owner will install own slab on top of well. Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Don Hirsh Business name Reda License No. 190 Address Box 1442 Dodge City, KS Signed Carl B. Smith Date 5-22-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5