

OFFICE USE ONLY

T

24

R

19

EM

SEC

31

NW 1/4 SE 1/4 SW 1/4

1 LOCATION OF WATER WELL  
 County: Edwards Fraction NW 1/4 SE 1/4 SW 1/4 Section Number 31 Township Number T 24 S Range Number R 19 EW

Distance and direction from nearest town or city? 2 W 1/4 N 1/4 E Street address of well if located within city?  
N-side of road from Kinsley

2 WATER WELL OWNER: Myron Run  
 RR#, St. Address, Box # :  
 City, State, ZIP Code : Kinsley, Ko. 67547 Board of Agriculture, Division of Water Resources  
 Application Number: 33447


3 DEPTH OF COMPLETED WELL 119 ft. Bore Hole Diameter 29 in. to 119 ft., and . . . . . in. to . . . . . ft.  
 Well Water to be used as:  
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well  
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)  
 7 Lawn and garden only 10 Observation well  
 Well's static water level 15' ft. below land surface measured on 4 month 10 day 80 year  
 Pump Test Data : Well water was 107 ft. after 1 hours pumping 500 gpm  
 Est. Yield 500 gpm: Well water was ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED:  
 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued . . . . . Clamped . . . . .  
 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded   
 Fiberglass Threaded . . . . .  
 Blank casing dia 10 in. to 81 ft., Dia in. to . . . . . ft., Dia in. to . . . . . ft.  
 Casing height above land surface 18 in., weight lbs./ft. Wall thickness or gauge No 7  
 TYPE OF SCREEN OR PERFORATION MATERIAL:  
 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement  
 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) . . . . .  
 None used (open hole)  
 Screen or Perforation Openings Are:  
 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)  
 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes  
 Torch cut 10 Other (specify) . . . . .  
 Screen-Perforation Dia 10 in. to 119 ft., Dia in. to . . . . . ft., Dia in. to . . . . . ft.  
 Screen-Perforated Intervals: From 81 ft. to 119 ft., From . . . . . ft. to . . . . . ft.  
 From . . . . . ft. to . . . . . ft., From . . . . . ft. to . . . . . ft.  
 Gravel Pack Intervals: From 10 ft. to 119 ft., From . . . . . ft. to . . . . . ft.  
 From . . . . . ft. to . . . . . ft., From . . . . . ft. to . . . . . ft.

5 GROUT MATERIAL:  Neat cement 2 Cement grout 3 Bentonite 4 Other . . . . .  
 Grouted Intervals: From 0 ft. to 10 ft., From . . . . . ft. to . . . . . ft., From . . . . . ft. to . . . . . ft.  
 What is the nearest source of possible contamination:  
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well  
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well  
 3 Lateral lines 6 Pit privy  Livestock pens 12 Insecticide storage 16 Other (specify below)  
 13 Watertight sewer lines  
 Direction from well E How many feet 3/4 mile? Water Well Disinfected? Yes . . . . . No   
 Was a chemical/bacteriological sample submitted to Department? Yes . . . . . No  If yes, date sample  
 was submitted . . . . . month . . . . . day . . . . . year: Pump Installed? Yes . . . . . No  
 If Yes: Pump Manufacturer's name Western Hard Roller Model No 6stage 10CM HP 40 Volts 440  
 Depth of Pump Intake 100 ft. Pumps Capacity rated at 450 gal./min.  
 Type of pump: 1 Submersible  Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was  constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was  
 completed on 7 month 30 day 80 year  
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 134  
 This Water Well Record was completed on 9 month 3 day 80 year under the business  
 name of Rosencrantz Bemis by (signature) Nora Dodson

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:



FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	2	Top soil			
2	18	Clay			
18	22	Blue Clay			
22	31	Blue sand & gravel w/ clay mixed			
31	42	Clay			
42	70	Clay w/ some sand & gravel mixed			
70	85	Sand & gravel			
85	87	Clay			
87	116	Sand & gravel			
116	120	Fire clay			

ELEVATION:  
 Depth(s) Groundwater Encountered 1. 15' ft. 2. . . . . ft. 3. . . . . ft. 4. . . . . ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.