

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Harvey	Fraction 1/4 NW 1/4 NW 1/4	Section number 2	Township number T 24 S R 2W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: #15 Cedar Ct. Halstead, KS			3. Owner of well: Dr. Don Holmen R.R. or street: #15 Cedar Ct. City, state, zip code: Halstead, KS			
4. Locate with "X" in section below: <div style="text-align: center;">N S 1 Mile</div>			Sketch map:			
5. Type and color of material			From	To	6. Bore hole dia. 11 in. Completion date 11-3-78 Well depth 45 ft.	
Topsoil			0	24	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay			3	24	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Fine Sand to Medium Sand			24	45	9. Casing: Material Styrene Height: Above or below 11/4 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200	
					10. Screen: Manufacturer's name Sunflower plastic Type styrene Dia. 5" Slot/gauge 1/4 .06 Length 20' Set between 25 ft. and 45 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4-1/8"	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 25 ft. below land surface Date 11-3-78	
					12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/>	
					14. Well head completion: 12 capped <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					15. Well grouted? yes 1-2 fine sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.	
					16. Nearest source of possible contamination: City ft. 55 Direction South Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation: Flat Ground		19. Remarks: Pump not installed at this time.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 6-19-79 Authorized representative		