


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Harvey</b>	<input checked="" type="checkbox"/> Fraction <b>NE 1/4 NW 1/4 NW 1/4</b>	Section number <b>2</b>	Township number <b>T 24 S R 2W 1/4W</b>	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: <b>#3 Cedar Drive Halstead, KS</b>			3. Owner of well: <b>Mary Alice Busse</b> R.R. or street: <b>#3 Cedar Drive</b> City, state, zip code: <b>Halstead, KS</b>		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>11</u> in. Completion date <u>10-28-78</u> Well depth <u>50</u> ft.
Topsoil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			3	25	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine sand to Medium sand			25	50	9. Casing: Material <u>Styrene</u> Height: Above or below <u>1111</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> g1 Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>      </u> lbs./ft. Dia. <u>5</u> in. to <u>50</u> ft. depth Wall Thickness: inches or Dia. <u>      </u> in. to <u>      </u> ft. depth gauge No. <u>.200</u>
					10. Screen: Manufacturer's name <u>Sunflower plastic</u> Type <u>styrene</u> Dia. <u>5"</u> Slot <u>1/16"</u> Length <u>20'</u> Set between <u>30</u> ft. and <u>50</u> ft. <u>      </u> ft. and <u>      </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>
					11. Static water level: <u>25</u> ft. below land surface Date <u>10-28-78</u> mo./day/yr.
					12. Pumping level below land surfaces: <u>      </u> ft. after <u>      </u> hrs. pumping <u>      </u> g.p.m. <u>      </u> ft. after <u>      </u> hrs. pumping <u>      </u> g.p.m. Estimated maximum yield <u>      </u> g.p.m.
					13. Water sample submitted: <u>      </u> mo./day/yr. <u>      </u> Yes <u>      </u> No Date <u>      </u>
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade
					15. Well grouted? <u>yes</u> <u>1-2</u> fine sand mix With: <u>      </u> Neat cement <u>      </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>40"</u> ft. to <u>14</u> ft.
					16. Nearest source of possible contamination: ft. <u>55</u> Direction <u>East</u> Type <u>City Sewer</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <u>      </u> Not installed Manufacturer's name <u>Jacuzzi</u> Model number <u>7S4C</u> HP <u>3/4</u> Volts <u>230</u> Length of drop pipe <u>40</u> ft. capacity <u>18</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <u>      </u> Turbine <u>      </u> Jet <u>      </u> Reciprocating <u>      </u> Centrifugal <u>      </u> Other
(Use a second sheet if needed)					
18. Elevation:  Topography: <u>      </u> Hill <u>      </u> Slope <u>      </u> Upland <u>      </u> Valley	19. Remarks:  <b>Flat Ground</b>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Harp Well &amp; Pump</b> 236 Business name License No. Address <b>Wichita, Kansas</b> 67209 Signed <u>M. Arnold</u> Date <u>10-28-78</u> Authorized representative		