


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <i>Harvey</i>	Fraction <i>NW 1/4 NW 1/4 NE 1/4</i>	Section number <i>7</i>	Township number <i>T 24 S</i>	Range number <i>R 2 E</i>
2. Distance and direction from nearest town or city:		<i>3 1/2 W of Halstead on the south</i>		3. Owner of well: <i>Harold Kechn</i>		
Street address of well location if in city:		<i>Halstead, Kansas</i>		R.R. or street: <i>Route 2</i>		
4. Locate with "X" in section below:		Sketch map: <i>side of the road. Halstead, Kansas</i>		6. Bore hole dia. <i>5</i> in. Completion date <i>3-26-76</i> Well depth <i>80</i> ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
<i>Topsoil</i>		<i>0 6</i>		9. Casing: Material <i>stycast</i> Height: <i>12</i> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <i>12</i> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <i>12</i> lbs./ft.		
<i>Brown Clay</i>		<i>6 18</i>		Dia. <i>5</i> in. to <i>80</i> ft. depth Wall Thickness: inches or Dia. <i>5</i> in. to <i>80</i> ft. depth gage No. <i>200</i>		
<i>Fine Sand</i>		<i>18 32</i>		10. Screen: Manufacturer's name <i>Superflex Plastic</i> Type <i>Stepless</i> Dia. <i>5 1/2</i> Slot/gauze <i>1/16</i> Length <i>20'</i> Set between <i>60</i> ft. and <i>80</i> ft.		
<i>Gray Clay</i>		<i>32 36</i>		Gravel pack? <i>yes</i> Size range of material <i>1/4-1/8"</i>		
<i>Fine Sand</i>		<i>36 49</i>		11. Static water level: <i>19</i> ft. below land surface Date <i>3-26-76</i> mo./day/yr.		
<i>Medium Sand</i>		<i>49 80</i>		12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____		
				14. Well head completion: <i>12 Capped</i> ____ Pitless adapter ____ Inches above grade		
				15. Well grouted? <i>yes</i> With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <i>40</i> to <i>14</i> ft.		
				16. Nearest source of possible contamination: <i>None</i> ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: ____ Hill ____ Slope ____ Upland ____ Valley		<i>Flat Ground</i> <i>Septic Not Installed</i> <i>when well was drilled.</i> <i>no apparent source for contamination</i>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Harold Mel + Pump 236</i> Business name <i>W. White, Kans</i> Address <i>W. White, Kans</i> Signed <i>M. Orsola</i> Date <i>3-30-76</i> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5