

| | | | | |
|---------------------------|-----------------------|----------------|-----------------|--------------|
| 1 LOCATION OF WATER WELL: | Fraction | Section Number | Township Number | Range Number |
| County: Harvey | SE ¼ SE ¼ NE ¼ | 2 | T 24 S | R 2 E |

Distance and direction from nearest town or city street address of well if located within city?

325 E. Tenth St., Halstead, Kansas

| | | |
|-------------------------|---------------------|---|
| 2 WATER WELL OWNER: | LEGG COMPANY INC. | Board of Agriculture, Division of Water Resources |
| RR#, St. Address, Box # | 325 E. TENTH STREET | Application Number: |
| City, State, ZIP Code | HALSTEAD, KS 67056 | |

| | |
|--|---|
| 3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: | 4 DEPTH OF COMPLETED WELL: 38.5 ft. ELEVATION: 0 |
| | Depth(s) Groundwater Encountered 14.06 ft. 2. ft. 3. ft. |
| | WELL'S STATIC WATER LEVEL 14.06 ft. below land surface measured on mo/day/yr 3/3/04 |
| | Pump test data: Well water was NA ft. after hours pumping gpm |
| | Est. Yield NA gpm: Well water was ft. after hours pumping gpm |
| | Bore Hole Diameter 12.75 in. to 38.5 ft. and in. to ft. |
| WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well | |
| 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) | |
| 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well | |
| Was a chemical/bacteriological sample submitted to Department? Yes No <input checked="" type="checkbox"/> If yes, mo/day/yr sample was submitted | |
| Water Well Disinfected? Yes No <input checked="" type="checkbox"/> | |

| | | | |
|--|---|--------------------|---|
| 5 TYPE OF BLANK CASING USED: | 5 Wrought iron | 8 Concrete tile | CASING JOINTS: Glued Clamped |
| 1 Steel | 3 RMP (SR) | 6 Asbestos-Cement | 9 Other (specify below) |
| 2 PVC | 4 ABS | 7 Fiberglass | Welded |
| Blank casing diameter 6 in. to 28 ft. Dia | | | Threaded <input checked="" type="checkbox"/> |
| Casing height above land surface 2.25 in., weight | | | lbs./ft. Wall thickness or gauge No. Sch. 40 |
| TYPE OF SCREEN OR PERFORATION MATERIAL | | | |
| 1 Steel | 3 Stainless steel | 5 Fiberglass | 7 PVC |
| 2 Brass | 4 Galvanized steel | 6 Concrete tile | 8 RMP (SR) |
| SCREEN OR PERFORATION OPENINGS ARE: | 5 Gauzed wrapped | 8 Saw cut | 11 None (open hole) |
| 1 Continuous slot | 3 Mill slot | 9 Drilled holes | |
| 2 Louvered shutter | 4 Key punched | 10 Other (specify) | |
| SCREEN-PERFORATED INTERVALS: | From 28 ft. to 38 ft. | From ft. to ft. | |
| | From ft. to ft. | From ft. to ft. | |
| GRAVEL PACK INTERVALS: | From 25.2 ft. to 38.5 ft. | From ft. to ft. | |
| | From ft. to ft. | From ft. to ft. | |

| | | | | |
|---|--------------------------------------|---|---------------------------|---------------------------------|
| 6 GROUT MATERIAL: | 1 Neat cement | 2 Cement grout | 3 Bentonite | 4 Other |
| Grout Intervals: From 0 ft. to 2 ft. | From 2 ft. to 19.8 ft. | From 19.8 ft. to 25.2 ft. | | |
| What is the nearest source of possible contamination: | | | | |
| 1 Septic tank | 4 Lateral lines | 7 Pit privy | 10 Livestock pens | 14 Abandoned water well |
| 2 Sewer lines | 5 Cess pool | 8 Sewage lagoon | 11 Fuel storage | 15 Oil well/Gas well |
| 3 Watertight sewer lines | 6 Seepage pit | 9 Feedyard | 12 Fertilizer storage | 16 Other (specify below) |
| Direction from well? East | | | 13 Insecticide storage | Sewer line |
| | | | How many feet? 120 | |

| FROM | TO | LITHOLOGIC LOG | FROM | TO | PLUGGING INTERVALS |
|------|------|--|------|------|--|
| 0 | 0.2 | Grass and roots, | 27.8 | 33 | Sand, fine to coarse grained, trace silt, |
| 0.2 | 1 | Clay and gravel fill, | 33 | 38.5 | Sand, fine to coarse grained, trace silt, Gray |
| 1 | 2.5 | Clay, silty, medium consistency, Dark Brown | | | |
| 2.5 | 4.5 | Clay, silty, trace sand, Black | | | |
| 4.5 | 6 | Clay, silty, medium consistency, Brown | | | |
| 6 | 6.8 | Silt, clayey, soft consistency, Pale Brown | | | |
| 6.8 | 7.8 | Clay, some silt, stiff consistency, Dark Brown | | | |
| 7.8 | 10.8 | Clay, silty, stiff consistency, Dark Brown | | | |
| 10.8 | 13.8 | Clay, silty, medium consistency, Dark Grayish | | | |
| 13.8 | 16 | Clay, silty, medium consistency, Dark Grayish | | | |
| 16 | 18.8 | Silt, clayey, soft consistency, | | | |
| 18.8 | 21.8 | Clay, silty, medium consistency, Dark Grayish | | | |
| 21.8 | 23.6 | Clay, trace silt, trace sand, Dark Gray | | | PW1, Abovegrade |
| 23.6 | 25 | Clay, silty, trace oxidized limestone, Mottled | | | Project Name: BM - Halstead |
| 25 | 27.8 | Silt, sandy, trace clay, Dark Gray | | | GeoCore # 1122, # |

| |
|---|
| 7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 3/2/2004 and this record is true to the best of my knowledge and belief. |
| Kansas Water Well Contractor's License No. 527 This Water Well Record was completed on (mo/day/yr) 4/17/2004 |
| under the business name of GeoCore, Inc. by (signature) <i>Don Kell</i> |