

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

OFFERLE
NW

1. Location of well:		County Hodgeman	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 4	Township number T 24 S R 22	Range number 22
2. Distance and direction from nearest town or city: 7 mi. S 2W, 1 1/2 SE of Hanston.			3. Owner of well: John Walker R.R. or street: Searville, Kansas 67876			
4. Locate with "X" in section below:			Sketch map:			
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 6-2-77	
Topsoil			0	4	Well depth 240 ft.	
Clay			4	15	7. Cable tool <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Driven <input type="checkbox"/> Dug	
Blue Shale			15	50	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay			50	75	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
Sandrock			75	100	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock	
Yellow Clay			100	105	<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gray Clay			105	135	9. Casing: Material plastic Height above or below	
Red Clay			135	185	Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in.	
Rock and sandrock			185	240	RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.	
BRICK 15'					Dia. 5 in. to 180 ft. depth Wall Thickness: inches or	
CRETACEOUS WELL					Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 320	
(Use a second sheet if needed)					10. Screen: Manufacturer's name Sunflower	
					Type RMP Dia. 5 in.	
					Slot 1/16 Dia. 60 ft.	
					Set between 180 ft. and 240 ft.	
					Gravel pack? yes Size range of material 1/8	
					11. Static water level: 95 ft. below land surface Date 6-1-77	
					12. Pumping level below land surfaces:	
					120 ft. after 2 hrs. pumping 10 g.p.m.	
					15 ft. after 1 hr. pumping 15 g.p.m.	
					Estimated maximum yield 15 g.p.m.	
					13. Water sample submitted: no. /day/yr.	
					Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date	
					14. Well head completion: 18 inches above grade	
					<input type="checkbox"/> Pitless adapter <input type="checkbox"/> 18 inches above grade	
					15. Well grouted? yes	
					With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete	
					Depth: From 0 ft. to 30 ft.	
					16. Nearest source of possible contamination:	
					From 50 ft. Direction south Type old well	
					Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: Not installed	
					Manufacturer's name Windmill	
					Model number 168 HP 4 volts	
					Length of drop pipe 168 ft. capacity 4 g.p.m.	
					Type:	
					<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
					<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
					<input type="checkbox"/> Centrifugal cylinder Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:		Abandoned and filled with concrete.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input checked="" type="checkbox"/> Hill		Concrete slab was installed.		Knoefler Bros. Drilling		
<input type="checkbox"/> Slope		TCPO 2355		Business name Letmore License No. 130		
<input type="checkbox"/> Upland				Address Letmore		
<input type="checkbox"/> Valley				Signed Dale Knoefler Date 6-27-77		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5