

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

SPEARVILLE NE

CA (center)

1. Location of well:		County Hodgeman	Fraction <del>SE</del> 1/4 NE 1/4 SW 1/4	Section number 3	Township number T 24 S	Range number R 23
2. Distance and direction from nearest town or city: 5 south, 3 east 1 south of Jetmore Street address of well location if in city:			3. Owner of well: Earl Schaffer Jetmore, KS 67854 City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 6. Bore hole dia. 26 in. Completion date 7-22-76 Well depth 110 ft. 7. Cable tool Rotary Driven <input checked="" type="checkbox"/> Dug Hollow rod Jetted Bored Reverse rotary 8. Use: Domestic Public supply Industry <input checked="" type="checkbox"/> Irrigation Air conditioning Stock Lawn Oil field water Other 9. Casing: Material steel Height: Above or below Threaded Welded <input checked="" type="checkbox"/> Surface 12 in. RMP PVC Weight 36.87 lbs./ft. Dia 16 in. 111 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No.			
5. Type and color of material			From	To	10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze Length 30" Set between 73 ft. and 103 ft. Perf: 103-110 and Gravel pack? yes Size range of material 1/4" Down 11. Static water level: mo./day/yr. 64 ft. below land surface Date 12. Pumping level below land surfaces: 97 ft. after 4 hrs. pumping 825 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 800 g.p.m. 13. Water sample submitted: mo./day/yr. Yes No Date 14. Well head completion: Pitless adapter 12 inches above grade 15. Well grouted yes With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: N/A ft. Direction Type Field Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No 17. Pump: Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: Submersible Turbine Jet Reciprocating Centrifugal Other	
18. Elevation: Topography: Hill <input checked="" type="checkbox"/> Slope Upland Valley			19. Remarks: WC = 2434-64 = 2370 2434 103 Customer Furnished Pump TOPO			
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. Address Box A Garden City, KS 67841 Signature Date 7-24-76 Authorized representative						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The*  
**Professionals**

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

PAUL COLLETT  
ROCKY HILL COUNTRY  
6-23-76

Location: 24-24-23 31 ft. east of test 35 in field  
static water level- 53'

Test 7

0	3	Top soil
3	9	Brown clay
9	19	White rock clay mixed
19	23	Brown sandy clay brown rock mixed hard pull down
23	42	Fine to med. sand gravel some yellow white rock
42	55	Brown sandy clay
55	73	Fine to med. sand gravel coarse yellow white rock (loose)
73	78	Fine to med. sand gravel coarse yellow white rock (thgt)
78	103	Fine to med. sand gravel coarse yellow white rock
103	105	Yellow clay hard
105	108	Shale

T.D. 110  
Screen 30