

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

SPEARVILLE NW

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DLID

1. Location of well:		County Hodgeman	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 30	Township number T 24 S R 23	Range number 23
2. Distance and direction from nearest town or city: 3 mi north-1/2 east-7 north-1 east of Wright			3. Owner of well: Raymond Fagen R.R. or street: Spearville, Kansas City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 4 1/2 in. Completion date _____ Well depth 402 ft. 3-30-77		
				7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
Surface		0	3	9. Casing: Material Metal Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC ___ Weight 31.66 lbs./ft. Dia. 16 in. to 402 ft. depth Wall thickness _____ inches or Dia. ___ in. to ___ ft. depth gage No. 188		
Sandy brown clay		3	16	10. Screen: Manufacturer's name _____ W.A. Brown Type 10% Free-flo Dia. 16 Slot/gauze 1/8 Length 140 Set between 137 ft. and 157 ft. 277 ft. and 397 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/2 down		
Yellow clay		16	25	11. Static water level: _____ mo./day/yr. 120 ft. below land surface Date 3-30-77		
Dark blue shale with rock layers		25	80	12. Pumping level below land surfaces: 265 ft. after 5 hrs. pumping 650 g.p.m. 300 ft. after 10 hrs. pumping 950 g.p.m. Estimated maximum yield 1000 g.p.m.		
Shale with 30% sandstone mixed		80	85	13. Water sample submitted: _____ mo./day/yr. ___ Yes <input checked="" type="checkbox"/> No Date _____		
Gray and red shale		85	112	14. Well head completion: ___ Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Sandy gray shale		112	141	<input checked="" type="checkbox"/> Well grouted? no With: ___ Neat cement ___ Bentonite ___ Concrete Depth: From _____ ft. to _____ ft.		
Good clean gray sandstone		141	150	16. Nearest source of possible contamination: field ft. _____ Direction _____ Type _____ Well disinfected upon completion? ___ Yes <input checked="" type="checkbox"/> No		
Gray sandstone with 50% shale mixed		150	152	17. Pump: _____ Not installed Manufacturer's name Goulds Model number 10JHC HP 100 Volts _____ Length of drop pipe 380 ft. capacity 600 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
Hard rock		152	153			
Gray shale with hard rock layers		153	276			
Good clean sandstone med. tight		276	315			
Good coarse tan sandstone		315	339			
Shale		339	340			
Good coarse tan sandstone		340	358			
Blue shale with 30% sandstone layers		358	395			
Blue shale		395	403			
<p>TRUCK 16'</p> <p>2293</p> <p>CRITICAL CASE WELL</p> <p>(Use a second sheet if needed)</p>						
18. Elevation: TOPO	19. Remarks: 10' of concrete pump slab to be installed by the customer. He knows this is a regulation grouting done by Raymond Fagen		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Ks Signed Carl Botz Date 4-30-77 Authorized representative			

T 24
R 23
S 30
SE SE SE
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5