

West Well

SPEARVILLE
NWUSE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.WATER WELL RECORD
KSA 82a-1201-1215Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BBB

1. Location of well:	County Hodgeman	Fraction SW NW 1/4 NW 1/4	Section number 10	Township number T 24 S	Range number R 24 E W																																																						
2. Distance and direction from nearest town or city: 7 mi south and three west of Jetmore, Ks Street address of well location if in city:			3. Owner of well: W. W. Schraeder R.R. or street: Star Rt. City, state, zip code: Jetmore, Kansas																																																								
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			6. Bore hole dia. 28 in. Completion date Well depth 130 ft. 12-21-77																																																								
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																																																								
<table border="1"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr><td>Surface</td><td>0</td><td>3</td></tr> <tr><td>Brown and tan clay</td><td>3</td><td>25</td></tr> <tr><td>Colecho sandrock and clay</td><td>25</td><td>62</td></tr> <tr><td>Med. sand with 5% clay</td><td>62</td><td>70</td></tr> <tr><td>Tan clay</td><td>70</td><td>78</td></tr> <tr><td>Med. sand and fine gravel</td><td>78</td><td>85</td></tr> <tr><td>50% clay-50% fine sand</td><td>85</td><td>88</td></tr> <tr><td>Good med. coarse to coarse sand and gravel</td><td>88</td><td>104</td></tr> <tr><td>Extra good coarse sand and gravel</td><td>104</td><td>113</td></tr> <tr><td>Hard rock</td><td>113</td><td>114</td></tr> <tr><td>Good med. to coarse sand and gravel</td><td>114</td><td>120</td></tr> <tr><td>Yellow clay</td><td>120</td><td>125</td></tr> <tr><td>Blue shale</td><td>125</td><td>130</td></tr> <tr><td colspan="3">Brock 120'</td></tr> <tr><td colspan="3">60</td></tr> <tr><td colspan="3">60' set back</td></tr> <tr><td colspan="3">111 of</td></tr> </tbody> </table>				From	To	Surface	0	3	Brown and tan clay	3	25	Colecho sandrock and clay	25	62	Med. sand with 5% clay	62	70	Tan clay	70	78	Med. sand and fine gravel	78	85	50% clay-50% fine sand	85	88	Good med. coarse to coarse sand and gravel	88	104	Extra good coarse sand and gravel	104	113	Hard rock	113	114	Good med. to coarse sand and gravel	114	120	Yellow clay	120	125	Blue shale	125	130	Brock 120'			60			60' set back			111 of			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
	From	To																																																									
Surface	0	3																																																									
Brown and tan clay	3	25																																																									
Colecho sandrock and clay	25	62																																																									
Med. sand with 5% clay	62	70																																																									
Tan clay	70	78																																																									
Med. sand and fine gravel	78	85																																																									
50% clay-50% fine sand	85	88																																																									
Good med. coarse to coarse sand and gravel	88	104																																																									
Extra good coarse sand and gravel	104	113																																																									
Hard rock	113	114																																																									
Good med. to coarse sand and gravel	114	120																																																									
Yellow clay	120	125																																																									
Blue shale	125	130																																																									
Brock 120'																																																											
60																																																											
60' set back																																																											
111 of																																																											
			9. Casing: Material metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia. 16 in. to 130 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188																																																								
			10. Screen: Manufacturer's name W. A. Brown & Johnson #100 Type 100 Free 110 Dia. 16 Slot/gauze 1/8 Length 70 Set between 60 ft. and 130 ft. ft. and ft. Gravel pack? yes Size range of material 1/2 down																																																								
			11. Static water level: mo./day/yr. 60 ft. below land surface Date 12-21-77																																																								
			12. Pumping level below land surfaces: 95 ft. after 2 hrs. pumping 1400 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1500 g.p.m.																																																								
			13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date																																																								
			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade																																																								
			15. Well grouted? no With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From ft. to ft.																																																								
			16. Nearest source of possible contamination: ft. Direction Type field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																																																								
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 12JIC HP 80 Volts Length of drop pipe 120 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																																								
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Kansas Signed Carl C. Little Date 12-21-77 Authorized representative																																																								
19. Remarks: 10' of concrete and motor slab to be installed by the customer, he knows this is a regulation 2499 W. W. Schraeder																																																											

24 240 10
R
Sec
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5