

## WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
COUNTY: HODGEMAN		SW 1/4 SW 1/4 NW 1/4	30	T 24 S	R 24 W

Distance and direction from nearest town or city street address of well if located within city?  
14TH & 50 BYPASS - 11 MILES NORTH, 2 EAST AND 1 1/2 SOUTH

2 WATER WELL OWNER:		VIOLA ECCLESTON (NORTH) <i>used</i>	Board of Agriculture, Division of Water Resources
RR#, St. Address, Box #: BOX 45			Application Number:
City, State, ZIP code: WRIGHT, KS 67801-			

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 268 ELEVATION: 0																									
<table border="1"> <tr> <td>1</td> <td>---</td> <td>NW</td> <td>---</td> <td>NE</td> <td>---</td> </tr> <tr> <td>2</td> <td>---</td> <td>---</td> <td>---</td> <td>---</td> <td>---</td> </tr> <tr> <td>3</td> <td>---</td> <td>---</td> <td>---</td> <td>---</td> <td>---</td> </tr> <tr> <td>4</td> <td>---</td> <td>SW</td> <td>---</td> <td>SE</td> <td>---</td> </tr> </table>		1	---	NW	---	NE	---	2	---	---	---	---	---	3	---	---	---	---	---	4	---	SW	---	SE	---	Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft. WELL'S STATIC WATER LEVEL 149 ft. below land surface measured on mo/day/yr 02/25/92 Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm Estimated Yield 50 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm Bore Hole Diameter 10 in. to 268 ft., and in. to 0 ft. WELL WATER TO BE USED AS: DOMESTIC Was a chemical/bacteriological sample submitted to department? No; If yes, mo/day/yr sample was submitted Water well disinfected? Yes	
1	---	NW	---	NE	---																						
2	---	---	---	---	---																						
3	---	---	---	---	---																						
4	---	SW	---	SE	---																						

5 TYPE OF BLANK CASING USED: PVC		CASING JOINTS: GLOED	
Blank casing diameter 5 in. to 268 ft., Dia in. to 0 ft., Dia in. to 0 ft.			
Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21			
TYPE OF SCREEN OR PERFORATION MATERIAL: PVC			
SCREEN OR PERFORATION OPENINGS ARE: SAW CUT			

SCREEN PERFORATED INTERVALS:	From 220 ft. to 260 ft., From 0 ft. to 0 ft.
	From 0 ft. to 0 ft., From 0 ft. to 0 ft.
GRAVEL PACK INTERVALS:	From 40 ft. to 268 ft., From 0 ft. to 0 ft.
	From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE	
Grout Intervals: From 0 ft. to 40 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.	
What is the nearest source of possible contamination: ABANDONED WELL	
Direction from well? WEST	How many feet? 300

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	5	TOPSOIL			
5	18	LINESTONE PINE SAND			
18	140	BLUE SHALE			
140	160	GRAY CLAY SANDSTONE			
160	180	SANDSTONE			
180	237	SANDSTONE			
237	240	ROCK LAYERS			
240	265	SANDSTONE			
265	300	GRAY CLAY			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 02/28/92 and this record is true to the best of my knowledge and belief. Kansas	
Water Well Contractor's License No. 179	This Water Well Record was completed on (mo/day/yr) 03/18/92
under the business name of JOE'S WELL SERVICE, INC.	by (signature) <i>Joel C. Crib</i>