


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ACA

1. Location of well:		County Hodgeman	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 12	Township number T 24 S R 25	Range number 1/W
2. Distance and direction from nearest town or city: 5 south, 6 west, Street address of well location if in city: 1 1/2 south, 1/4 west of Jetmore.				3. Owner of well: Duane Denton R.R. or street: City, state, zip code: Jetmore, Ks. 67854		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile				Sketch map: 		
5. Type and color of material				From	To	
<p>BR 67</p> <p>39</p> <p>2 8' salt water</p> <p>2505</p> <p>67</p> <p>2438 ✓</p> <p>1" Dg</p>						
6. Bore hole dia. 26 in. Completion date 8-31-76 Well depth 77 ft.						
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary						
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other						
9. Casing: Material steel Height: Above grade Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 78 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250						
10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 47 ft. and 67 ft. Perf: 40-47 ft. and 67-77 ft. Gravel pack? yes Size range of material 1/2" down						
11. Static water level: <input type="checkbox"/> mo./day/yr. 39 ft. below land surface Date 7-20-76						
12. Pumping level below land surfaces: 65 ft. after 3 hrs. pumping 450 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 450 g.p.m.						
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.						
14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter						
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.						
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Customer's Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: Customer furnished the pump.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. Address Box A Garden City, Ks. Signed [Signature] Date 5-20- Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5



WINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 27-6169 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Duaine Denton
Hodgeman County
1-27-76

Location: From old windmill, 1000' East NGL 12-24-25

Test #3

0	3	Top soil
3	7	White clay
7	16	Brown sandy clay
16	23	Fine sand
23	31	Fine to med. sand & gravel
31	37	Brown sandy clay
37	67	Fine to med. sand, gravel mixed with yellow white rock (loose)
67	69	Yellow clay
69	71	Shale

Static Water level: 40

T.D. 77' 00"